PRIMARY DRINKING WATER CONTAMINANTS MAXIMUM CONTAMINANT LEVELS (MCLs):

Antimony	6	ppb	(parts per billion)
Arsenic	10	ppb	
Barium	2000	ppb	
Beryllium	4	ppb	
Cadmium	5	ppb	
Chromium	100	ppb	
Copper	1300	ppb	
Lead	15	ppb	
Mercury	2	ppb	
Selenium	50	ppb	
Thallium	2	ppb	
Nitrate/Nitrite	10	ppm	(parts per million)
Fluoride	4	ppm	

SECONDARY DRINKING WATER CONTAMINANTS MAXIMUM CONTAMINANT LEVELS (MCLs):

Aluminum	50 to 200	ppb
Copper	1000	ppb
Iron	300	ppb
Manganese	50	ppb
Silver	100	ppb
Zinc	5000	ppb
Sulfate	250	ppm
Total Dissolved Solids	500	ppm
Fluoride	2	ppm