

## Minimum Requirements – Generator

- Liquid-cooled engine
- AC alternator
- Weather-protective enclosure
- Vibration shock mounts
- Gauges for battery voltmeter, water temperature, oil pressure, and run-time
- 3-position mode switch (auto-off-manual)
- Extra quiet muffler and rain cap equipped exhaust pipe
- Over current warning and shutdown
- Over and under voltage/frequency shutdown
- Over-speed shutdown
- Low oil pressure warning and shutdown
- High/Low coolant temperature warning and shutdown
- High/low/weak battery voltage warning
- Fail to start shutdown
- Fail to crank shutdown
- Redundant start disconnect
- Optional remote display/control panel
- Auxiliary relay for dry contacts
- Emergency stop button
- Sized to power mission critical dispatch center systems including E911 controller(s), telephones/telephone system, radio console(s), logging and instant recall recorders, mapping, TTY/TDD, and computer-aided dispatch
- Two-year minimum on-site warranty (parts & labor)