

Minimum Requirements – Uninterruptible Power Supply (UPS)

(Note: This is sometimes referred to as a “back room” system)

- Sized to power mission critical dispatch center systems including E911 controller(s), telephones/telephone system, radio console(s), logging and instant recall recorders, mapping, TTY/TDD, and computer-aided dispatch for a minimum of 1 hour
- Requires connectivity to dispatch floor receptacles as well as to the generator/commercial power via transfer switch
- Automatic UPS bypass on overload or UPS failure
- Sealed lead-acid batteries (not required for non-battery powered systems)
- Internal maintenance bypass
- Top and bottom cable entry (not required for units installed outside)
- One year on-site warranty (parts and labor)
- Meets UL and CUL standards
- User friendly control/monitoring display
- Input for external emergency power off (EPO)