



Department of
**Environment &
Conservation**

Underground Storage Tank Enforcement Update

Underground Storage Tanks and
Solid Waste Disposal Control Board
December 3, 2025

Rhonda Key, Environmental Manager

ENFORCEMENT OVERVIEW

The Division issued 89 orders between July 1, 2025, and September 30, 2025.

- 40 are Fund Orders of those Fund Orders.
 - 5 in Final status.
 - 4 in Final-Remediation
 - 5 Appealed
 - 12 Closed.
 - 8 in Signed Status.
 - 6 in Signed-Pending SOP status
- 49 are Compliance orders of those orders.
 - 8 in Final status
 - 5 Appealed
 - 12 in Signed Status
 - 20 in Signed-Pending SOP status
 - 1 was Non-Suited
 - 3 Closed

Enforcement Overview (cont'd)

From July 1, 2025, to September 30, 2025:

The Division assessed \$381,844 in civil penalties.

Final Orders

Final Order

Summary of FDA25-0051

Fac. ID No. 7-230211/ Trimble Food Express, Jackson, Dyer County

- Fund Deductible Amount Order signed July 28, 2025.
- Violations Alleged in the Order:
 - Failure to ensure that cathodic protection system is tested within six months of installation and every three years thereafter.
 - Failure to maintain the results of testing.
 - Failure to install, calibrate, operate, or maintain release detection method for piping in accordance with the manufacturer's instructions.
- The Application for Fund Eligibility was approved with a deductible of \$20,000.
- The order became final September 4, 2025.

Final Order

Summary of FDA25-0052

Fac. ID No. 5-630457/ Circle K 4703915, Nashville, Montgomery County

- Fund Deductible Amount Order signed July 28, 2025.
- Violations Alleged in the Order:
 - Failure to report a suspected release to the division within 72 hours after discovery of released petroleum.
 - Failure to conduct annual line tightness test or do monthly monitoring on pressurized underground piping .
 - Failure to repair, replace or close the UST system and begin corrective action if test results indicate that a release exists
 - Failure to conduct a system test when there is a suspected release to determine whether a leak exists
- The Application for Fund Eligibility was approved with a deductible of \$30,000.
- The order became final October 26, 2025.

Final Order

Summary of FDA26-0003

Fac. ID No. 7-230122/ Dodge's Store, Jackson, Dyer County

- Fund Deductible Amount Order signed September 15, 2025.
- Violations Alleged in the Order:
 - Failure to operate and maintain corrosion protection system.
 - Failure to ensure that electronic and mechanical components are tested annually for proper operation.
 - Failure to conduct annual line tightness test or do monthly monitoring on pressurized underground piping
 - Failure to test line leak detectors annually
 - Failure to report a confirmed release to the Division within 72 hours.
- The Application for Fund Eligibility was approved with a deductible of \$30,000.
- The order became final October 19, 2025.

Final Order

Summary of FED25-0012

Fac. ID No. 2-470803/ Weigel's No. 23, Knoxville, Knox County

- Fund Deductible Amount Order signed August 25, 2025.
- Violations Alleged in the Order:
 - Failure of piping installed after July 25, 2007, to be 100% double walled or secondarily contained.
 - Failure to report a suspected release to the Division within 72 hours.
 - Failure to obtain Division approval prior to permanent closure.
 - Failure to conduct a site check.
 - Failure to submit the application for fund eligibility within 90 days of the suspected release.
- The Application for Fund Eligibility was denied.

Final Order

Summary of UST25-0031

Fac. ID No. 5-191292/ XPO, Inc.-BNA, Nashville, Davison County

- Director's Order signed August 8, 2025.
- Violations Alleged in the Order:
 - Failure to conduct release investigation activities.
 - Failure to cooperate.
- Penalty:
 - Total fees and penalties: \$2,400.
- The Order became final on September 13, 2025.

Final Order

Summary of UST25-0041

Fac. ID No. 9-790723/ Murphy Express No. 8708, Nashville, Wilson County

- Director's Order signed August 19, 2025.
- Violations Alleged in the Order:
 - Failure to install or provide adequate overfill prevention system.
 - Failure to cooperate.
- Penalty:
 - Total fees and penalties: \$2,400.
- The Order became final on September 23, 2025.

Final Order

Summary of UST25-0056

Fac. ID No. 5-190935/ Circle K. 4703935, Nashville, Davidson County

- Director's Order signed July 14, 2025.
- Violations Alleged in the Order:
 - Failure to install other system parts in accordance with manufacture's installation instructions.
 - Failure to cooperate.
- Penalty:
 - Total fees and penalties: \$2,400.
- The Order became final on August 18, 2025.

Final Order

Summary of UST25-0058

Fac. ID No. 2-471198/ Casey's General Store No. 4207, Knoxville, Knox County

- Director's Order signed August 19, 2025.
- Violations Alleged in the Order:
 - Failure to install other system parts in accordance with manufacture's installation instructions.
 - Failure to cooperate.
- Penalty:
 - Total fees and penalties: \$9,600.
- The Order became final on September 29, 2025.

Final Order

Summary of UST25-0076

Fac. ID No. 2-471461/ Casey's General Store No. 4048, Knoxville, Knox County

- Director's Order signed September 2, 2025.
- Violations Alleged in the Order:
 - Failure to conduct a system test when there is a suspected release exists.
 - Failure to cooperate.
- Penalty:
 - Total fees and penalties: \$3,840.
- The Order became final on October 6, 2025.

Final Order

Summary of UST25-0083

Fac. ID No. 4-670032/ Livingston Regional Hospital, Cookeville, Overton County

- Director's Order signed August 8, 2025.
- Violations Alleged in the Order:
 - Failure of facility having one or more petroleum Ust systems to have one or more Class A, Class B, and Class C operators.
 - Failure to report a change of status for a UST system within 30 days.
 - Failure to cooperate.
- Penalty:
 - Total fees and penalties: \$4,560.
- The Order became final on September 21, 2025.

Final Order

Summary of UST25-0102

Fac. ID No. 3-700060/ Mona and Larry's, Chattanooga, Polk County

- Director's Order signed August 28, 2025.
- Violations Alleged in the Order:
 - Failure to monitor tanks at least monthly.
 - Failure to ensure that the cathodic protection system is tested every three years.
 - Failure to cooperate.
- Penalty:
 - Total fees and penalties: \$3,840.
- The Order became final on October 5, 2025.

Final Remediation Orders

Final Remediation Order

Summary of FDA25-0042

Fac. ID No. 9-791246/ B&G Express, Memphis, Shelby County

- Fund Deductible Amount Order signed July 7, 2025.
- Violations Alleged in the Order:
 - Failure to install, calibrate, operate, or maintain release detection for tank in accordance with manufacturer's instructions.
 - Failure to test spill prevention equipment at least once every three years.
 - Failure to inspect overfill prevention equipment at least once every three years.
 - Failure to conduct annual line tightness test on pressurized underground piping.
 - Failure to test line leak detectors annually

Final Remediation Order-Continued

Summary of FDA25-0042

Fac. ID No. 9-791246/ B&G Express, Memphis, Shelby County

- Fund Deductible Amount Order signed July 7, 2025.
- The Application for Fund Eligibility was approved with a deductible of \$20,000.
- The order became final August 21, 2025.

Final Remediation Order

Summary of FDA25-0043

Fac. ID No. 5-190998/ Mapco No. 3307, Nashville, Davidson County

- Fund Deductible Amount Order signed July 15, 2025.
- Violations Alleged in the Order:
 - Failure to install, calibrate, operate, or maintain release detection for piping in accordance with manufacturer's instructions.
 - Failure to report a suspected release to the Division within 72 hours.
- The Application for Fund Eligibility was approved with a deductible of \$30,000.
- The order became final August 18, 2025.

Final Remediation Order

Summary of FDA25-0047

Fac. ID No. 5-420035/ Sudden Service No. 42, Nashville, Houston County

- Fund Deductible Amount Order signed July 15, 2025.
- Violations Alleged in the Order:
 - Failure to report a suspected release to the Division within 72 hours.
 - Failure to report a confirmed release to the Division within 72 hours.
- The Application for Fund Eligibility was approved with a deductible of \$30,000.
- The order became final August 18, 2025.

Final Remediation Order

Summary of FDA25-0057

Fac. ID No. 2-470684/ Ian's Market No. 31, Knoxville, Knox County

- Fund Deductible Amount Order signed July 23, 2025.
- Violations Alleged in the Order:
 - Failure to provide release detection method capable of detecting a release from tank that routinely contains product.
- The Application for Fund Eligibility was approved with a deductible of \$20,000.
- The order became final August 18, 2025.

Appealed Orders

Appealed Order

Summary of FDA25-0041

Fac. ID No. 5-220193/ Old Columbia Market, Nashville, Dickson County

- Fund Deductible Amount Order signed July 10, 2025.
 - Violations Alleged in the Order:
 - Failure to repair, replace or close the UST system and begin corrective action if test results indicate that a release exists
 - Failure to inspect overfill prevention equipment at least once every three years
 - Failure to perform an annual walkthrough inspection
 - Failure to maintain the results of testing
 - Failure to install, calibrate, operate or maintain release detection method for piping.
- The Application for Fund Eligibility was approved with a deductible of \$20,000.
- Penalty:
 - Total fees and penalties: \$5,200.
- The order was appealed on October 10, 2025.

Appealed Order

Summary of FDA25-0045

Fac. ID No. 7-17001/ ABC Mart, Jackson, Crockett County

- Fund Deductible Amount Order signed September 23, 2025.
- Violations Alleged in the Order:
 - Failure to report a suspected release in 72 hours.
 - Failure to install, calibrate, operate, or maintain release detection method for tank in accordance with manufacturer's instructions
 - Failure to maintain results of annual testing of electronic and mechanical components for three Years
 - Failure to install or provide adequate overfill prevention system
 - Failure to inspect overfill prevention equipment at least once every three years
 - Failure to repair, replace or close the UST system if test results indicate that a release exists
 - Failure to report a change of status for a UST system within 30 days

Appealed Order-Continued

Summary of FDA25-0045-Continued

Fac. ID No. 7-17001/ ABC Mart, Jackson, Crockett County

- Fund Deductible Amount Order signed September 23, 2025.
- The Application for Fund Eligibility was approved with a deductible of \$30,000.
- Penalty:
 - Total fees and penalties: \$7,000.
- The order was appealed on October 28, 2025.

Appealed Order

Summary of FDA25-0055

Fac. ID No. 9-790600/ Dodge's Store, Memphis, Shelby County

- Fund Deductible Amount Order signed July 22, 2025.
- Violations Alleged in the Order:
 - Failure to install, calibrate, operate, or maintain release detection method for piping in accordance with manufacturer's instructions
 - Failure to test line leak detectors annually
 - Failure to report a suspected release to the division within 72 hours after discovery of released petroleum
 - Failure to repair, replace or close the UST system and begin corrective action if test results indicate that a release exists
- The Application for Fund Eligibility was approved with a deductible of \$30,000.
- Penalty:
 - Total fees and penalties: \$6,400.
- The order was appealed on October 10, 2025.

Appealed Order

Summary of FED25-0006

Fac. ID No. 9-791551/ Mapco Express No. 3253, Memphis, Shelby County

- Fund Eligibility Denial Order signed June 24, 2025.
 - Violations Alleged in the Order:
 - Failure to repair, replace or close the UST system and begin corrective action if test results indicate that a release exists.
 - Failure to comply with requirements concerning design, construction, unitization and or upgrade of corrosion protection for piping.
 - Failure to report a suspected release to the Division within 72 hours.
 - Failure to inspect overfill prevention equipment at least once every three years.
 - Failure to monitor tanks at least monthly
 - Failure to conduct annual line tightness test on pressurized underground piping
 - Failure to test line leak detectors annually.
 - Failure to report a confirmed release to the Division within 72 hours.
 - Failure to submit the application for fund eligibility within 90 days of the suspected release.

Appealed Order-Continued

Summary of FED25-0006-Continued

Fac. ID No. 9-791551/ Mapco Express No. 3253, Memphis, Shelby County

- Fund Eligibility Denial Order signed June 24, 2025.

- The Application for Fund Eligibility is denied.

- Penalty:
 - Total fees and penalties: \$13,000.

- The order was appealed on July 25, 2025.

Appealed Order

Summary of FED25-0013

Fac. ID No. 9-791972/ RNC Enterprise, LLC, Memphis, Shelby County

- Fund Deductible Amount Order signed July 7, 2025.
- Violations Alleged in the Order:
 - Failure to report a suspected release to the Division within 72 hours.
 - Failure to repair, replace or close the UST system if test results indicate that a release exists.
 - Failure to conduct a system test when there is a suspected release to determine whether a leak exists in the tank.
 - Failure to submit the application for fund eligibility within 90 days of the suspected release.
- The Application for Fund Eligibility is denied.
- Penalty:
 - Total fees and penalties: \$8,400.
- The order was appealed on August 12, 2025.

Appealed Order

Summary of UST24-0225

Fac. ID No. 9-791238/ Five Star Express, Memphis, Shelby County

- Director's Order signed August 7, 2025.
- Violations Alleged in the Order:
 - Failure to have a spill prevention system that will prevent a release of petroleum to the environment.
 - Failure to have adequate overfill prevention equipment.
 - Failure to install, calibrate, operate or maintain a release detection method for piping and tanks.
 - Failure to report a change of status for a UST system within 30 days.
 - Failure to operate and maintain corrosion protection system.
 - Failure to ensure that cathodic protection system is tested within six months of installation and every three years thereafter.
 - Failure to inspect impressed current corrosion protection systems every 60 days.
 - Failure to cooperate with the Division.

Appealed Order

Summary of UST24-0225

Fac. ID No. 9-791238/ Five Star Express, Memphis, Shelby County

- Director's Order signed August 7, 2025.
- Penalty:
 - Total fees and penalties: \$34,080.
- The Order was appealed on September 25, 2025.

Appealed Order

Summary of UST25-0063

Fac. ID No. 3-580029/ Hale's Bar Marina, Chattanooga, Marion County

- Director's Order signed August 27, 2025.
- Violations Alleged in the Order:
 - Failure to maintain a log of at least the last twelve (12) months of visual inspections.
 - Failure to conduct annual line tightness test on pressurized underground piping.
 - Failure to test electronic and mechanical components at least annually.
 - Failure to test line leak detectors annually.
 - Failure to cooperate with the Division.

Appealed Order - Continued

Summary of UST25-0063

Fac. ID No. 3-580029/ Hale's Bar Marina, Chattanooga, Marion County

- Director's Order signed August 27, 2025.
- Penalty:
 - Total fees and penalties: \$7,560.
- The Order was appealed on October 6, 2025.

Appealed Order

Summary of UST25-0093

Fac. ID No. 3-330063/ Farm Life, LLC, Chattanooga, Hamilton County

- Director's Order signed August 25, 2025.
- Violations Alleged in the Order:
 - Failure to permanently close an UST system where the impressed current cathodic protection system has been turned off or has been inoperable for more than 12 months.
 - Failure to continue operation and maintenance of release detection in a temporarily closed tank.
 - Failure of a facility having one or more petroleum UST systems to have one or more persons designated as Class A, Class B, and Class C Operators.
 - Failure to ensure that a cathodic protection system is tested every three years.
 - Failure to inspect an impressed current corrosion protection system every 60 days.
 - Failure to cooperate with the Division.

Appealed Order - Continued

Summary of UST25-0093

Fac. ID No. 3-330063/ Farm Life, LLC, Chattanooga, Hamilton County

- Director's Order signed August 25, 2025.
- Penalty:
 - Total fees and penalties: \$30,480.
- The Order was appealed on September 4, 2025.

Appealed Order

Summary of UST25-0095

Fac. ID No. 1-370171/ Skipez D/B/A Skipez, Inc, Johnson City, Hawkins County

- Director's Order signed August 28, 2025.
- Violations Alleged in the Order:
 - Failure to report a change of status for a UST system within 30 days.
 - Failure of a facility having one or more petroleum UST systems to have one or more persons designated as Class A, Class B, and Class C Operators.
 - Failure to cooperate with the Division.
- Penalty:
 - Total fees and penalties: \$5,280.
- The Order was appealed on October 17, 2025.

Appealed Order

Summary of UST25-0110

Fac. ID No. 1-900301/ Circle A Market, Johnson City, Washington County

- Director's Order signed September 22, 2025.
- Violations Alleged in the Order:
 - Failure to ensure that cathodic protection is functioning as designed and is effectively preventing corrosion.
 - Failure to ensure that a cathodic protection system is tested every three years.
 - Failure to inspect an impressed current corrosion protection system every 60 days
 - Failure to cooperate with the Division.
- Penalty:
 - Total fees and penalties: \$5,280.
- The Order was appealed on October 24, 2025.

Closed Orders

Closed Order

Summary of FDA25-0031

Fac. ID No. 9-792706/ Murphy Oil USA No. 726, Memphis, Shelby County

- Fund Deductible Amount Order signed July 1, 2025
- Violations Alleged in the Order:
 - Failure to install, calibrate, operate or maintain release detection method for piping.
 - Failure to perform periodic walkthrough inspections.
 - Failure to have adequate overfill.
- The Application for Fund Eligibility was approved with a deductible of \$10,000.
- The remediation case has been closed and there were no compliance issues or civil penalties assessed. The case was closed August 22, 2025.

Closed Order

Summary of FDA25-0044

Fac. ID No. 2-320405/ TM0036, Knoxville, Hamblen County

- Fund Deductible Amount Order signed July 15, 2025
- Violations Alleged in the Order:
 - Failure to report a suspected release to the Division within 72 hours.
 - Failure to install, calibrate, operate or maintain release detection method for a tank.
- The Application for Fund Eligibility was approved with a deductible of \$30,000.
- The Order was closed. The Order went final with no remedial action, and a release was not confirmed. The case was closed August 22, 2025.

Closed Order

Summary of FDA25-0049

Fac. ID No. 2-470880/ Ian's Market No. 41, Knoxville, Knox County

- Fund Deductible Amount Order signed July 15, 2025
- Violations Alleged in the Order:
 - Failure to report a suspected release to the Division within 72 hours.
 - Failure to install, calibrate, operate or maintain release detection method for a tank.
- The Application for Fund Eligibility was approved with a deductible of \$30,000.
- The Order was closed. The Order went final with no remedial action, and a release was not confirmed. The case was closed August 22, 2025.

Closed Order

Summary of FDA25-0050

Fac. ID No. 2-730044/ Gateway Texaco, Knoxville, Roane County

- Fund Deductible Amount Order signed July 10, 2025
- Violations Alleged in the Order:
 - Failure to permanently close a substandard UST system.
- The Application for Fund Eligibility was approved with a deductible of \$20,000.
- The remediation case has been closed and there were no compliance issues or civil penalties assessed. The case was closed August 26, 2025.

Closed Order

Summary of FDA25-0053

Fac. ID No. 9-792716/ Kroger Fuel Center No. 405, Memphis, Shelby County

- Fund Deductible Amount Order signed September 3, 2025
- Violations Alleged in the Order:
 - Failure to operate and maintain overfill equipment in good working condition.
- The Application for Fund Eligibility was approved with a deductible of \$10,000.
- The remediation case has been closed and there were no compliance issues or civil penalties assessed. The case was closed September 23, 2025.

Closed Order

Summary of FDA26-0002

Fac. ID No. 9-792615/ Circle K Store No. 470367, Memphis, Shelby County

- Fund Deductible Amount Order signed September 3, 2025
- Violations Alleged in the Order:
 - Failure to report a suspected release to the Division within 72 hours.
- The Application for Fund Eligibility was approved with a deductible of \$30,000.
- The remediation case has been closed and there were no compliance issues or civil penalties assessed. The case was closed October 13, 2025.

Closed Order

Summary of FED25-0005

Fac. ID No. 9-792693/ Murphy USA No. 6908, Memphis, Shelby County

- Fund Eligibility Denial Order signed July 7, 2025
- Violations Alleged in the Order:
 - Failure to perform periodic walkthrough inspections.
 - Failure to have overfill prevention.
 - Failure to report a release in 72 hours.
- The Application for Fund Eligibility was denied.
- The remediation case has been closed and there were no compliance issues or civil penalties assessed. The case was closed August 22, 2025.

Closed Order

Summary of FED25-0009

Fac. ID No. 2-730195/ Iyan Investments, Knoxville, Roane County

- Fund Eligibility Denial Order signed August 6, 2025
- Violations Alleged in the Order:
 - Failure to submit the application for fund eligibility within 90 days of the suspected release.
- The Application for Fund Eligibility was denied.
- The remediation case has been closed and there were no compliance issues or civil penalties assessed. The case was closed September 15, 2025.

Closed Order

Summary of FED25-0010

Fac. ID No. 2-780194/ White Star Market, Knoxville, Sevier County

- Fund Eligibility Denial Order signed July 28, 2025
- Violations Alleged in the Order:
 - Failure to maintain results of annual testing of electronic and mechanical components for three years.
 - Failure to install or provide adequate overfill prevention system.
 - Failure of containment sumps used for interstitial monitoring of piping to be tested every three years.
 - Failure to submit the application for fund eligibility within 90 days of the suspected release
- The Application for Fund Eligibility was denied.
- The remediation case has been closed and there were no compliance issues or civil penalties assessed. The case was closed September 22, 2025.

Closed Order

Summary of FED25-0014

Fac. ID No. 5-830232/ Hendersonville Keystop Express, Nashville, Sumner County

- Fund Eligibility Denial Order signed July 28, 2025
- Violations Alleged in the Order:
 - Failure to operate and maintain corrosion protection system in accordance with a corrosion expert's design.
 - Failure to monitor tanks at least monthly.
 - Failure to conduct annual line tightness test or do monthly monitoring on pressurized underground piping.
 - Failure to inspect overfill prevention equipment at least once every three years.
 - Failure to monitor spill prevention equipment for UST systems.
 - Failure to report a confirmed release to the Division within 72 hours.
 - Failure to submit the application for fund eligibility within 90 days of the suspected release.

Closed Order-Continued

Summary of FED25-0014-Continued

Fac. ID No. 5-830232/ Hendersonville Keystop Express, Nashville, Sumner County

- Fund Eligibility Denial Order signed July 28, 2025
- The Application for Fund Eligibility was denied.
- The remediation case has been closed and civil penalties received. The case was closed September 11, 2025.

Closed Order

Summary of FED25-0016

Fac. ID No. 9-791846/ Circle K 4703957, Memphis, Shelby County

- Fund Eligibility Denial Order signed July 29, 2025
- Violations Alleged in the Order:
 - Failure to install, calibrate, operate, or maintain release detection method for tank and piping in accordance with manufacturer's instructions.
 - Failure to test line leak detectors annually.
 - Failure to report a suspected release to the Division within 72 hours after discovery of released petroleum.
 - Failure to submit the application for fund eligibility within 90 days of the suspected release.
- The Application for Fund Eligibility was denied.
- The remediation case has been closed and there were no compliance issues or civil penalties assessed. The case was closed September 3, 2025.

Closed Order

Summary of UST25-0071

Fac. ID No. 9-792656/ J's BP, Memphis, Shelby County

- Director's Order signed July 1, 2025
- Violations Alleged in the Order:
 - Failure to install other system parts.
 - Failure to cooperate.
- Penalty:
 - Total fees and penalties: \$2,400.
- The civil penalty was paid, and facility is back in compliance. The case was closed on September 8, 2025.

Closed Order

Summary of UST25-0096

Fac. ID No. 2-730040/ Shrini, Inc., D/B/A Midtown Quick Stop, Knoxville, Roane County

- Director's Order signed September 3, 2025.
- Violations Alleged in the Order:
 - Failure to tightness test a UST system after three months but no later than six months.
 - Failure to report a suspected release to the Division within 72 hours.
 - Failure to cooperate.
- Penalty:
 - Total fees and penalties: \$7,200.
- The civil penalty was paid, and facility is back in compliance. The case was closed on October 15, 2025.

Closed Order

Summary of UST25-0109

Fac. ID No. 9-792221/ Blue Linx Corporation, Memphis, Shelby County

- Director's Order signed August 25, 2025.
- Violations Alleged in the Order:
 - Failure to have a spill prevention system that will prevent the release of petroleum to the environment when the transfer hose is detached from the fill pipe.
 - Failure to cooperate.
- Penalty:
 - Total fees and penalties: \$2,400.
- The civil penalty was paid, and facility is back in compliance. The case was closed on October 3, 2025.

Non-Suit Orders

Non-Suit Order

Summary of UST25-0098

Fac. ID No. 9-791291/ Hop In No. 333, Memphis, Shelby County

- Director's Order signed September 5, 2025.
- Violations Alleged in the Order:
 - Failure of facility having one or more petroleum UST systems to have one or more persons designated as Class A, Class B, and Class C operators.
 - Failure to cooperate.
- Penalty:
 - Total fees and penalties: \$4,560.
- There was an issue with the designations that was resolved. The Order was non-suited and the penalty waived on October 8, 2025.

Orders Final or Appealed from Previous Quarter

Final Order

Summary of FDA25-0038

Fac. ID No. 1-820109/ Cupboard Food Market, Johnson City, Sullivan County

- Fund Deductible Amount Order signed April 23, 2025.
- Violations in Order:
 - Failure of facility having one or more petroleum UST systems to have one or more persons designated as Class A, Class B, and Class C Operators.
 - Failure to conduct annual line tightness test or do monthly monitoring on pressurized underground piping.
 - Failure to conduct a system test when there is a suspected release.
 - Failure to report a change of status for a UST system within 30 days.
- The Application for Fund Eligibility was approved with a deductible of \$20,000.
- The order became final June 5, 2025. Respondent paid \$18,400 in full and case was closed.

Final Order

Summary of FED25-0003

Fac. ID No. 5-740013/ AM Express 1, Nashville, Robertson County

- Fund Eligibility Denial Order signed April 24, 2025.
- Violations in Order:
 - Failure to install, calibrate, operate, or maintain release detection method for tank in accordance with manufacturer's instructions.
 - Failure to report a suspected release to the Division within 72 hours.
 - Failure to monitor tanks at least monthly, if appropriate.
 - Failure to repair, replace or close the UST system if test results indicate that a release exists.
- The Application for Fund Eligibility is denied.
- The order became final June 6, 2025. **Agreed Final Order reached. Respondent to pay \$15,904 plus \$285 for service of process in 12 payments. Respondent must repair or close Tank 4A and will be on probation for one year.**

Appealed Order

Summary of FDA25-0024

Fac. ID No. 2-050315/ Gas Express, Knoxville, Blount County

- Fund Deductible Amount Order signed April 22, 2025.
 - Violations in Order:
 - Failure to test electronic and mechanical components at least annually.
 - Failure to monitor tanks at least monthly.
 - Failure of facility having one or more petroleum UST systems to have one or more persons designated as Class A, Class B, and Class C Operators.
- The Application for Fund Eligibility was approved with a deductible of \$10,000.
- Penalty:
 - Total fees and penalties: \$23,000.
- The order was appealed on May 28, 2025. **Agreed Final order reached. Respondent will pay \$16,330 and \$160 in 12 payments. The remaining \$6,670 will be contingent on one year probation.**

Appealed Order

Summary of UST24-0266

Fac. ID No. 3-3100812/ Summerfield Market, Chattanooga, Grundy County

- Director's Order signed May 5, 2025.
- Violations in Order:
 - Failure to have a spill bucket lid that is in good condition and not in contact with the fill cap.
 - Failure of facility having one or more UST systems to have one or more trained persons designated as Class A, Class B, and Class C Operators.
 - Failure to cooperate with the Division.
- Penalty:
 - Total fees and penalties: \$4,680.
- The Order was appealed on June 12, 2025. **Agreed Final Order reached. Respondent will pay \$2,808 and \$245 for service of process. The remaining \$1,872 is contingent on one year probation.**