

Deferred underground storage tank systems include the following:

1. Wastewater treatment tank systems;
2. UST systems containing radioactive material that are regulated under the Atomic Energy Act;
3. Any UST system that is part of an emergency generator system at nuclear power generation facilities regulated by the Nuclear Regulatory Commission;
4. Airport hydrant fuel distribution systems;
5. UST systems with field-constructed tanks;
6. Equipment or machinery that contains petroleum for operational purposes such as hydraulic lift tanks and electrical equipment tanks;
7. Any UST system whose capacity is 110 gallons or less;
8. Any UST system that contains a de minimis concentration of petroleum; or
9. Any emergency spill or overflow containment UST system that is expeditiously emptied after use.