

**Public Record Summary Information on Underground Storage Tanks (USTs)
From 10/1/2020 To 9/30/2021 General Information**

Total Number of Active UST Facilities: 5,060

Total Number of Active UST Tanks: 16,078

Summary Information for On-Site Inspections

Number of UST Facilities Inspected: 2,197

Inspection Period: 10/1/2020 To 9/30/2021

Percent Compliance

Release Prevention: 91.87%

Release Detection: 85.18%

Combined Compliance: 75.31%

Note: Tanks, facility, and on-site inspection information is based on underground storage tanks regulated under Subtitle I that satisfy the definition of UST in 40 CFR 280.12, except for those tanks identified in 40 CFR 280.10(b) as excluded USTs. On-site inspections measure compliance with release detection and release prevention (significant operational compliance (SOC)/technical compliance rate (TCR), state regulations, Subtitle I, etc.).

Summary Information for Releases

Number of Confirmed UST Releases: 134

Release Reporting Period: 10/1/2020 To 9/30/2021

Summary Information for Release Sources and Causes

Source/Location			Cause												
			Spill		Overfill		Phys/Mech Damage		Corrosion		Install Problems		Other		unknown
#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	10	7.46					5	50.00						5	50.00
Piping	5	3.73					5	100.00							
Dispenser	3	2.24					1	33.33						2	66.67
STP	2	1.49					1	50.00						1	50.00
Delivery Problem		0.00													
Other		0.00													
Unknown	114	85.07												114	100.00
Total	134	100.00					12	8.96						122	91.04

= number % = percent of total number

Note: Release, source and cause information is based on underground storage tanks regulated under subtitle I that satisfy the definition of UST in 40 CFR 280.12. This report reflects data from releases reported to the department during the time period of the report. Source and cause data were collected using on-site inspections and reports from facilities.

Additional information on site-specific USTs, such as compliance or releases may be obtained through contacting the Tennessee Division of Underground Storage Tanks at 615-532-0945.