


ADDENDUM NO. 2
CONTRACT 23-01 ARPA SEWER REHABILITATION
SAVANNAH, TENNESSEE
WAUFORD PROJECT NO. 3711

Date of Addendum: Friday, May 3, 2024
Bid Opening: 11:00 am Thursday, May 9, 2024

1. Plans Sheet 1, Clarifications:

- The existing sewer pipe material is PVC.
- If a contractor needs to access a manhole on the airport property, the contractor shall notify the airport prior to entering. There is no additional certifications or insurance required.
- There are no existing videos of the existing sewers to be released.

J. R. WAUFORD & COMPANY,
CONSULTING ENGINEERS, INC.



W. Scott Daniel, P.E.
Tennessee License No. 104425