

**FALL CREEK FALLS STATE
DAM REPAIR**

FALL CREEK FALLS STATE PARK
2009 VILLAGE CAMP ROAD
PIKEVILLE, TN 37367

Contractor is to furnish all labor, materials, equipment necessary to repair a leak in the dam.

Contractor shall conduct dives to pinpoint the cause of the leak.

Contractor shall provide all materials necessary to repair the leak.

Contractor will be required to dive and repair the leak under water.

Contractor shall remove the 6'x 6' plate to allow for water to be discharged out of the 16" valve in order for the water to be lowered in the lake.

Contractor shall install a 24 inch suction pipe to reduce the lake level, transition box, termination box and the 24 inch butterfly valve.

Contractor shall install a new gate valve, new thrust nut, reinstall bronze stem to the valve assembly and disenable the electric operator for the valve.

Contractor is to remove all trash and debris and dispose of off park grounds.

Contractor will be responsible to repair, replace any damage to the buildings or grounds at no cost to the State of TN.

Contractor is to start work 20 days after receipt of purchase order has been issued and 60 days to complete this project.

Contractor is to furnish a 1year warranty on workmanship upon final inspection and acceptance by the State of Tn. Payment will be made after final inspection and acceptance has been issued.