

**PICKWICK LANDING STATE PARK
116 STATE PARK LANE, COUNCE, TN 38326
WASTEWATER TESTING & MONITORING SPECIFICATIONS**

Testing and Monitoring of Pickwick Landing State Park Wastewater Treatment Facility. A Grade 1 Wastewater Treatment system is for a system with treatment of seventy-five thousand (75,000) gallons per day or less. This classification serves as a collection system with less than fifteen (15) service connections.

Respondents may schedule a site visit prior to submitting a proposal by contacting

Sydney Loomans

Sydney.Loomans@tn.gov

615-253-7266

Requirements

- The Contractor shall maintain, and ensure at all times, that the following Tennessee Department of Environment and Conservation certification and licenses remain active, current, and in good standing:
 - Collection System Certification
 - Aerated Lagoon System Plant License
 - Biological Natural LicenseThe Respondent shall provide copies of the active license and certifications in their ITB bid response.
- The Respondent shall demonstrate prior experience by providing a minimum of two (2) references from current or completed projects or contracts of comparable scope.

Scope of Work

1. The Contractor shall be responsible for all required testing and shall insure the facility is in compliance with all applicable rules, regulations and laws as required by the Division of Water Pollution Control.
 - a. Test results shall be submitted through the U.S. Environmental Protection Agency's Central Data Exchange.
 - b. Copies of all test results shall be sent to the following address:
Pickwick Landing State Park & Water Pollution Control
362 Carriage House Drive, Jackson, TN 38305-2222
2. The Contractor shall provide all labor, equipment and materials necessary to conduct the specified tests.
 - a. Biological test for solids shall be conducted one (1) time per week
 - b. Fecal coliform test shall be conducted one (1) time per week
 - c. Settable solids test shall be conducted one (1) time per week
 - d. A test for chlorine and water quality at discharge end of system shall be performed five (5) days of every seven (7). This test shall check for oxygen levels, solids, and foreign matter as per Division of Water Quality Regulations

3. All required reports shall be compiled and submitted as required by the Division of Water Pollution Control.
4. The Contractor shall function as the Operator In Charge of Pickwick Landing State Park Wastewater Facility. The Operator In Charge shall be proficient with the procedures related to operating, calibrating, reading, modifying, and basic troubleshooting of all equipment.
5. Housekeeping functions, daily equipment check, routine maintenance, and repair shall be the responsibility of Pickwick Landing State Park.
6. A designated Park employee shall be present when the Contractor is on the premises.

Park Contact: Andy Wright, andrew.wright@tn.gov, Office 731-689-3129, Cell 423-309-9012

Invoices shall be sent to the Pickwick Landing State Park's Account Clerk <pickwicklanding.park@tn.gov>