



STATE OF TENNESSEE
DEPARTMENT OF MILITARY

**EVENT 34101-13716
AMENDMENT # ONE
FOR VAULT EXPANSION - Lexington**

DATE: September 5, 2025, 2025

EVENT # ONE IS AMENDED AS FOLLOWS:

1. State responses to questions and comments in the table below amend and clarify this Event.

Any restatement of Event text in the Question/Comment column shall NOT be construed as a change in the actual wording of the Event document.

QUESTION #	EVENT SECTION	QUESTION / COMMENT	STATE RESPONSE
1		Should we submit a bid on Concept 1 or Concept 2?	Concept 1
2		In the Terms document, it says If both, is there a place for both on the bid form?	The State is only accepting Concept 1.
3		Will one fourth inch steel plate be an acceptable alternate to the Marsten, Irving or pierced steel planking?	Because the Marsten is so hard to get in a new purchase, AR190-11 sub G-2f states "One fourth-inch steel plate" is authorized. Absolutely NO 16 gauge steel sheets anywhere in upgrading of vaults.

2. Event Amendment Effective Date. The revisions set forth herein shall be effective upon release. All other terms and conditions of this Event not expressly amended herein shall remain in full force and effect.