

Contract	Age	Cylinder	LBF	PSI	Area	P/F	Design	Required	Made	Tested	Fracture
S202	28	285	77398	6190	12.504	Pass	200401	3000	12/28/2020	1/25/2021	Cone & Shear
S202	28	285A	73664	5860	12.566	Pass	200401	3000	12/28/2020	1/25/2021	Cone & Split
U287	28	2	85148	6740	12.629	Pass	BAG MIX	3000	12/28/2020	1/25/2021	Cone & Shear
U287	28	2A	87818	6990	12.566	Pass	BAG MIX	3000	12/28/2020	1/25/2021	Columnar
R136	28	CG15	71116	5720	12.441	Pass	200401	3000	12/28/2020	1/25/2021	Cone & Shear
R136	28	CG15A	78542	6250	12.566	Pass	200401	3000	12/28/2020	1/25/2021	Cone
CMGC03	28	55ARK	127876	10180	12.566	Pass	200923	5000	12/28/2020	1/25/2021	Cone & Shear
CMGC03	28	55ARK	125522	9990	12.566	Pass	200923	5000	12/28/2020	1/25/2021	Columnar
T079	28	225A	72077	5740	12.566	Pass	200065	3000	12/28/2020	1/25/2021	Cone
T079	28	225A	69880	5560	12.566	Pass	200065	3000	12/28/2020	1/25/2021	Cone & Shear
U017	28	2ARB	138254	11000	12.566	Pass	200031	6000	12/28/2020	1/25/2021	Columnar
U017	28	2ARB	149289	11880	12.566	Pass	200031	6000	12/28/2020	1/25/2021	Cone
DB1801	28	505	80672	6420	12.566	Pass	200392	3000	12/28/2020	1/25/2021	Columnar
DB1801	28	505A	80819	6430	12.566	Pass	200392	3000	12/28/2020	1/25/2021	Cone
U287	28	3	101673	8090	12.566	Pass	BAG MIX	3000	12/29/2020	1/26/2021	Columnar
U287	28	3A	97316	7740	12.566	Pass	BAG MIX	3000	12/29/2020	1/26/2021	Cone & Shear
U012	28	9	57778	4600	12.566	Pass	200169	3000	12/29/2020	1/26/2021	Columnar
U012	28	9A	63351	5040	12.566	Pass	200169	3000	12/29/2020	1/26/2021	Columnar
U017	28	25	56947	4530	12.566	Pass		3000	12/29/2020	1/26/2021	Cone & Split
U017	28	25A	56137	4470	12.566	Pass		3000	12/29/2020	1/26/2021	Columnar
R136	28	61	86890	6910	12.566	Pass	200401	3000	12/29/2020	1/26/2021	Columnar
R136	28	62	84287	6710	12.566	Pass	200401	3000	12/29/2020	1/26/2021	Cone & Shear
106077	28	122A	83229	6620	12.566	Pass	200663	3000	12/29/2020	1/26/2021	Cone & Shear
106077	28	122A	86620	6890	12.566	Pass	200663	3000	12/29/2020	1/26/2021	Cone & Shear
T079	28	226A	71329	5680	12.566	Pass	200065	3000	12/29/2020	1/26/2021	Columnar
T079	28	226A	70262	5590	12.566	Pass	200065	3000	12/29/2020	1/26/2021	Cone & Shear
S127	28	274	91862	7310	12.566	Pass	200039	3000	12/29/2020	1/26/2021	Columnar
S127	28	274A	89752	7140	12.566	Pass	200039	3000	12/29/2020	1/26/2021	Cone
T359	28	95	73916	5880	12.566	Pass	210066	3000	12/29/2020	1/26/2021	Cone
T359	28	95A	70968	5650	12.566	Pass	210066	3000	12/29/2020	1/26/2021	Cone & Shear
U272	14	2B	66570	5300	12.566	Pass	210193	3000	1/12/2021	1/26/2021	Cone & Shear

U272	14	2C	72759	5790	12.566	Pass	210193	3000	1/12/2021	1/26/2021	Cone & Shear
U032	7	7B	64862	5160	12.566	Pass	210131	3000	1/19/2021	1/26/2021	Cone & Shear
U032	7	7C	66588	5300	12.566	Pass	210131	3000	1/19/2021	1/26/2021	Cone & Split
120439	28	12	40341	3210	12.566	Pass	210107	3000	12/29/2020	1/26/2021	Cone
120439	28	12A	39220	3120	12.566	Pass	210107	3000	12/29/2020	1/26/2021	Cone & Split
CMGC03	28	219	119285	9490	12.566	Pass	200923	3000	1/29/2020	1/26/2021	Cone & Shear
CMGC03	28	220	121761	9690	12.566	Pass	200923	3000	1/29/2020	1/26/2021	Columnar
CMGC03	28	91	99396	7910	12.566	Pass	210271	3000	12/29/2020	1/26/2021	Cone & Shear
CMGC03	28	91A	99271	7900	12.566	Pass	210271	3000	12/29/2020	1/26/2021	Cone & Shear
CMGC03	28	90	99190	7890	12.566	Pass	210271	3000	12/29/2020	1/26/2021	Cone
CMGC03	28	90A	96383	7670	12.566	Pass	210271	3000	12/29/2020	1/26/2021	Cone
R252	28	162	102275	8140	12.566	Pass	200312	3000	1/29/2020	1/26/2021	Columnar
R252	28	162A	99993	7960	12.566	Pass	200312	3000	1/29/2020	1/26/2021	Cone & Shear
S127	28	275	75701	6020	12.579	Pass	200039	4000	12/30/2020	1/27/2021	Columnar
S127	28	275A	68322	5440	12.566	Pass	200039	4000	12/30/2020	1/27/2021	Shear
U046	28	18	78682	6260	12.566	Pass	200169	3000	12/30/2020	1/27/2021	Cone & Shear
U046	28	18A	77872	6200	12.566	Pass	200169	3000	12/30/2020	1/27/2021	Columnar
106077	28	123A	81135	6460	12.566	Pass	200663	3000	12/30/2020	1/27/2021	Cone & Shear
106077	28	123A	80494	6410	12.566	Pass	200663	3000	12/30/2020	1/27/2021	Cone & Shear
106077	28	124A	45632	3630	12.566	Pass	200291	3000	12/30/2020	1/27/2021	Cone
106077	28	124A	48585	3870	12.566	Pass	200291	3000	12/30/2020	1/27/2021	Cone
S202	28	286	90879	7230	12.566	Pass	200142	4000	12/30/2020	1/27/2021	Cone & Shear
S202	28	286A	97379	7750	12.566	Pass	200142	4000	12/30/2020	1/27/2021	Columnar
S202	28	287	100442	7990	12.566	Pass	200142	4000	12/30/2020	1/27/2021	Cone & Shear
S202	28	287A	85855	6830	12.566	Pass	200142	4000	12/30/2020	1/27/2021	Cone & Shear
S202	28	288	95052	7560	12.566	Pass	200142	4000	12/30/2020	1/27/2021	Columnar
S202	28	288A	107504	8550	12.566	Pass	200142	4000	12/30/2020	1/27/2021	Columnar
S202	28	289	93480	7440	12.566	Pass	200142	4000	12/30/2020	1/27/2021	Cone & Shear
S202	28	289A	93342	7430	12.566	Pass	200142	4000	12/30/2020	1/27/2021	Cone & Split
T359	28	96	67558	5370	12.573	Pass	210066	3000	12/30/2020	1/27/2021	Cone
T359	28	96A	66857	5320	12.566	Pass	210066	3000	12/30/2020	1/27/2021	Cone & Split
T296	28	35	94520	7520	12.566	Pass	200277	3000	12/30/2020	1/27/2021	Cone & Split

T296	28	35A	100900	8030	12.566	Pass	200277	3000	12/30/2020	1/27/2021	Cone & Shear
CMGC03	28	92	96106	7650	12.566	Pass	210272	5000	12/30/2020	1/27/2021	Cone
CMGC03	28	92A	96750	7700	12.566	Pass	210272	5000	12/30/2020	1/27/2021	Cone
Q921	28	910	65193	5190	12.566	Pass	201101	3000	12/30/2020	1/27/2021	Columnar
Q921	28	910A	65111	5180	12.566	Pass	201101	3000	12/30/2020	1/27/2021	Cone & Shear
112454	28	1	61645	4910	12.566	Pass	200065	3000	12/30/2020	1/27/2021	Cone & Shear
112454	28	1A	60510	4820	12.566	Pass	200065	3000	12/30/2020	1/27/2021	Cone & Shear
120439	28	13	68334	5440	12.566	Pass	210107	3000	12/30/2020	1/27/2021	Cone & Shear
120439	28	13A	59471	4730	12.566	Pass	210107	3000	12/30/2020	1/27/2021	Cone & Shear
U057	28	15A	56463	4490	12.566	Pass	200456	3000	12/31/2020	1/28/2021	Cone & Shear
U057	28	15A	55103	4380	12.566	Pass	200456	3000	12/31/2020	1/28/2021	Cone & Shear
U299	14	6C	60521	4820	12.566	Pass	210118	3000	1/14/2021	1/28/2021	Cone
U032	7	8B	52814	4200	12.566	Pass	210131	3000	1/21/2021	1/28/2021	Columnar
U032	7	8C	53412	4250	12.566	Pass	210131	3000	1/21/2021	1/28/2021	Cone & Shear
U299	5	7B	29921	< 2380	12.566	Fail	210118	3000	1/25/2021	1/28/2021	Columnar
U299	5	7C	29630	< 2360	12.566	Fail	210118	3000	1/25/2021	1/28/2021	Cone & Split
S202	14	296C	52032	4140	12.566	Pass	200150	3000	1/15/2021	1/29/2021	Cone & Shear
S202	14	296C	51537	4100	12.566	Pass	200150	3000	1/15/2021	1/29/2021	Cone & Split
T925	7	203B	99784	7940	12.566	Pass	210197	3000	1/22/2021	1/29/2021	Cone & Shear
T925	7	203C	37699	3000	12.566	Pass	210197	3000	1/22/2021	1/29/2021	Cone & Split
S202	9	299B	64118	5100	12.566	Pass	210206	3000	1/20/2021	1/29/2021	Columnar
S202	9	299B	63287	5040	12.566	Pass	210206	3000	1/20/2021	1/29/2021	Cone & Shear
U264	8	1B	49229	3920	12.566	Pass		3000	1/21/2021	1/29/2021	Cone
U264	8	1C	55440	4410	12.566	Pass		3000	1/21/2021	1/29/2021	Cone