

Contract	Age	Cylinder	LBF	PSI	Area	P/F	Design	Required	Made	Tested	Fracture
CPI	28	10V	137262	10920	12.566	Pass		8000	7/22/2024	8/19/2024	Cone
CPI	28	10V	126609	10080	12.566	Pass		8000	7/22/2024	8/19/2024	Cone & Shear
CPI	28	11V	129339	10290	12.566	Pass		8000	7/22/2024	8/19/2024	Cone & Split
CPI	28	11V	124992	9950	12.566	Pass		8000	7/22/2024	8/19/2024	Cone & Shear
DB2101	28	294A	58856	4680	12.566	Pass		3000	7/22/2024	8/19/2024	Columnar
DB2101	28	294A	59825	4760	12.566	Pass		3000	7/22/2024	8/19/2024	Cone & Split
126644	28	12	63247	5030	12.566	Pass	240280	3000	7/22/2024	8/19/2024	Cone & Shear
126644	28	12A	61709	4910	12.566	Pass	240280	3000	7/22/2024	8/19/2024	Cone
U032	4	502B	54416	4330	12.566	Pass	240118	3000	8/15/2024	8/19/2024	Cone & Shear
U032	4	502B	51822	4120	12.566	Pass	240118	3000	8/15/2024	8/19/2024	Columnar
V009	28	231	52173	4150	12.566	Pass	240750	3000	7/22/2024	8/19/2024	Columnar
V009	28	231A	53636	4270	12.566	Pass	240750	3000	7/22/2024	8/19/2024	Columnar
V233	28	186A	62677	4990	12.566	Pass		3000	7/22/2024	8/19/2024	Cone & Split
V233	28	186A	64313	5120	12.566	Pass		3000	7/22/2024	8/19/2024	Cone
V282	28	95	46569	3710	12.566	Pass	240004	3000	7/22/2024	8/19/2024	Columnar
V282	28	95A	49247	3920	12.566	Pass	240004	3000	7/22/2024	8/19/2024	Columnar
V284	28	58A	66294	5360	12.379	Pass		3000	7/22/2024	8/19/2024	Columnar
V284	28	58A	65974	5250	12.566	Pass		3000	7/22/2024	8/19/2024	Columnar
W110	28	113	65571	5220	12.566	Pass	240426	3000	7/22/2024	8/19/2024	Cone & Split
W110	28	113A	68541	5450	12.566	Pass	240426	3000	7/22/2024	8/19/2024	Columnar
W181	30	144	69867	5560	12.566	Pass		4000	7/20/2024	8/19/2024	Cone & Shear
W181	30	144A	65356	5200	12.566	Pass		4000	7/20/2024	8/19/2024	Cone & Shear
W181	28	145	163166	5770	28.274	Pass		3000	7/22/2024	8/19/2024	Columnar
w181	28	145A	160971	5690	28.274	Pass		3000	7/22/2024	8/19/2024	Cone & Shear
W181	28	146	61701	4910	12.566	Pass		3000	7/22/2024	8/19/2024	Cone & Shear
W181	28	146A	63471	5050	12.566	Pass		3000	7/22/2024	8/19/2024	Columnar
W181	28	147	84358	6710	12.566	Pass		3000	7/22/2024	8/19/2024	Cone
W181	28	147A	79297	6310	12.566	Pass		3000	7/22/2024	8/19/2024	Cone & Shear
W181	7	166B	57629	4590	12.566	Pass	240321	4000	8/12/2024	8/19/2024	Cone
W181	7	166C	56643	4510	12.566	Pass	240321	4000	8/12/2024	8/19/2024	Shear
W231	28	38A	63281	5040	12.566	Pass		3000	7/22/2024	8/19/2024	Cone & Split

W231	28	38A	66979	5330	12.566	Pass		3000	7/22/2024	8/19/2024	Cone
W265	29	24A	80091	6340	12.629	Pass		4000	7/21/2024	8/19/2024	Cone & Shear
W265	29	24A	80032	6370	12.566	Pass		4000	7/21/2024	8/19/2024	Cone & Shear
W265	29	25A	80158	6380	12.566	Pass		4000	7/21/2024	8/19/2024	Cone & Split
W265	29	25A	76774	6110	12.566	Pass		4000	7/21/2024	8/19/2024	Columnar
W265	29	26A	70999	5650	12.566	Pass		4000	7/21/2024	8/19/2024	Shear
W265	29	26A	75233	5990	12.566	Pass		4000	7/21/2024	8/19/2024	Cone & Shear
X176	28	6A	40519	< 3220	12.566	Fail		4000	7/22/2024	8/19/2024	Columnar
X176	28	6A	35652	< 2840	12.566	Fail		4000	7/22/2024	8/19/2024	Columnar
X205	7	26B	59570	4740	12.566	Pass	240210	3000	8/12/2024	8/19/2024	Columnar
X205	7	26B	59942	4770	12.566	Pass	240210	3000	8/12/2024	8/19/2024	Columnar
X358	28	26A	72290	5750	12.566	Pass		4000	7/22/2024	8/19/2024	Columnar
X358	28	26A	72344	5760	12.566	Pass		4000	7/22/2024	8/19/2024	Columnar
X394	7	10B	54554	4340	12.566	Pass	240402	3000	8/12/2024	8/19/2024	Columnar
X394	7	10B	60480	4810	12.566	Pass	240402	3000	8/12/2024	8/19/2024	Cone
X412	28	1VRB	130865	10410	12.566	Pass		6000	7/22/2024	8/19/2024	Columnar
X412	28	1VRB	137349	10930	12.566	Pass		6000	7/22/2024	8/19/2024	Cone
Y034	28	2A	63707	5100	12.504	Pass		3000	7/22/2024	8/19/2024	Cone
Y034	28	2A	67613	5380	12.566	Pass		3000	7/22/2024	8/19/2024	Columnar
Y061	30	4A	116933	9350	12.504	Pass		3000	7/20/2024	8/19/2024	Cone & Split
Y061	30	4A	109957	8750	12.566	Pass		3000	7/20/2024	8/19/2024	Cone & Shear
Y061	30	5A	136627	10870	12.566	Pass		4000	7/20/2024	8/19/2024	Cone
Y061	30	5A	140832	11210	12.566	Pass		4000	7/20/2024	8/19/2024	Cone
Y061	30	6A	108075	8600	12.566	Pass		4000	7/20/2024	8/19/2024	Cone
Y061	30	6A	105955	8430	12.566	Pass		4000	7/20/2024	8/19/2024	Columnar
Y064	30	8A	78775	6270	12.566	Pass	240659	3000	7/20/2024	8/19/2024	Cone
Y064	30	8A	68286	5430	12.566	Pass	240659	3000	7/20/2024	8/19/2024	Cone & Shear
Y080	29	18A	61216	4870	12.566	Pass		3000	7/21/2024	8/19/2024	Columnar
Y080	29	18A	55236	4400	12.566	Pass		3000	7/21/2024	8/19/2024	Cone & Shear
Y080	28	19A	53707	4270	12.566	Pass		3000	7/22/2024	8/19/2024	Shear
Y080	28	19A	57487	4570	12.566	Pass		3000	7/22/2024	8/19/2024	Shear
Y096	30	7A	71671	5700	12.566	Pass		3000	7/20/2024	8/19/2024	Shear

Y096	30	7B	70917	5640	12.566	Pass		3000	7/20/2024	8/19/2024	Columnar
Y096	28	8A	71265	5670	12.566	Pass		3000	7/22/2024	8/19/2024	Columnar
Y096	28	8B	73649	5860	12.566	Pass		3000	7/22/2024	8/19/2024	Cone & Shear
Y138	29	3A	75418	6000	12.566	Pass		3000	7/21/2024	8/19/2024	Cone & Shear
Y138	29	3A	69130	5500	12.566	Pass		3000	7/21/2024	8/19/2024	Cone
126662	28	2	3934	310	12.566	Pass	240939	100	7/23/2024	8/20/2024	Cone
126662	28	2A	3571	280	12.566	Pass	240939	100	7/23/2024	8/20/2024	Columnar
DB2101	28	295A	67880	5400	12.566	Pass		3000	7/23/2024	8/20/2024	Columnar
DB2101	28	295A	75956	6040	12.566	Pass		3000	7/23/2024	8/20/2024	Cone & Shear
DB2101	28	296A	45675	3630	12.566	Pass		3000	7/23/2024	8/20/2024	Columnar
DB2101	28	296A	46820	3730	12.566	Pass		3000	7/23/2024	8/20/2024	Shear
DB2101	28	297A	45871	3650	12.566	Pass		3000	7/23/2024	8/20/2024	Shear
DB2101	28	297A	48833	3890	12.566	Pass		3000	7/23/2024	8/20/2024	Cone & Shear
W055	28	417A	74220	5910	12.566	Pass	240404	3000	7/23/2024	8/20/2024	Cone & Shear
W055	28	417A	76708	6100	12.566	Pass	240404	3000	7/23/2024	8/20/2024	Cone & Split
W110	28	114	67018	5330	12.566	Pass	240426	3000	7/23/2024	8/20/2024	Cone & Shear
W110	28	114A	68802	5480	12.566	Pass	240426	3000	7/23/2024	8/20/2024	Shear
W181	28	148	84644	6740	12.566	Pass		3000	7/23/2024	8/20/2024	Shear
W181	28	148A	78796	6270	12.566	Pass		3000	7/23/2024	8/20/2024	Cone & Shear
W231	28	39A	63246	5030	12.566	Pass		3000	7/23/2024	8/20/2024	Columnar
W231	28	39A	62986	5010	12.566	Pass		3000	7/23/2024	8/20/2024	Cone & Shear
W265	28	27A	80176	6380	12.566	Pass		4000	7/23/2024	8/20/2024	Cone
W265	28	27A	75512	6010	12.566	Pass		4000	7/23/2024	8/20/2024	Cone & Shear
W265	28	28A	74461	5930	12.566	Pass		4000	7/23/2024	8/20/2024	Shear
W265	28	28A	72501	5770	12.566	Pass		4000	7/23/2024	8/20/2024	Cone & Shear
W265	28	29A	66791	5320	12.566	Pass		4000	7/23/2024	8/20/2024	Cone & Shear
W265	28	29A	63073	5020	12.566	Pass		4000	7/23/2024	8/20/2024	Columnar
X119	28	88A	65958	5300	12.441	Pass		3000	7/23/2024	8/20/2024	Cone & Shear
X119	28	88A	70456	5610	12.566	Pass		3000	7/23/2024	8/20/2024	Shear
X135	28	21A	65542	5220	12.566	Pass	240433	3000	7/23/2024	8/20/2024	Cone & Split
X135	28	21A	69614	5540	12.566	Pass	240433	3000	7/23/2024	8/20/2024	Columnar
X142	28	7A	77004	6130	12.566	Pass		3000	7/23/2024	8/20/2024	Columnar

X142	28	7A	72465	5770	12.566	Pass		3000	7/23/2024	8/20/2024	Cone & Shear
X164	28	41	55492	4420	12.566	Pass	BAG MIX	3000	7/23/2024	8/20/2024	Columnar
X164	28	41A	53456	4250	12.566	Pass	BAG MIX	3000	7/23/2024	8/20/2024	Cone & Shear
X176	28	7A	46091	3670	12.566	Pass		3000	7/23/2024	8/20/2024	Columnar
X176	28	7A	45736	3640	12.566	Pass		3000	7/23/2024	8/20/2024	Columnar
X308	28	99A	83820	6670	12.566	Pass		3000	7/23/2024	8/20/2024	Cone
X308	28	99A	80845	6430	12.566	Pass		3000	7/23/2024	8/20/2024	Shear
X358	28	4VRB	132138	10520	12.566	Pass		10000	7/23/2024	8/20/2024	Cone & Shear
X358	28	4VRB	142440	11340	12.566	Pass		10000	7/23/2024	8/20/2024	Cone
X362	28	10	76747	6080	12.629	Pass		3000	7/23/2024	8/20/2024	Cone & Shear
X362	28	10A	71788	5710	12.566	Pass		3000	7/23/2024	8/20/2024	Cone & Shear
Y080	28	20A	57215	4550	12.566	Pass		3000	7/23/2024	8/20/2024	Columnar
Y080	28	20A	59657	4750	12.566	Pass		3000	7/23/2024	8/20/2024	Columnar
Y146	28	42V	145527	11580	12.566	Pass		10000	7/23/2024	8/20/2024	Cone & Shear
Y146	28	42V	148570	11820	12.566	Pass		10000	7/23/2024	8/20/2024	Cone
Y146	28	43V	156013	12420	12.566	Pass		10000	7/23/2024	8/20/2024	Cone
Y146	28	43V	146503	11660	12.566	Pass		10000	7/23/2024	8/20/2024	Cone
Y146	28	44V	149208	11870	12.566	Pass		10000	7/23/2024	8/20/2024	Cone
Y146	28	44V	142335	11330	12.566	Pass		10000	7/23/2024	8/20/2024	Cone
DB2101	28	298A	72289	5750	12.566	Pass		3000	7/24/2024	8/21/2024	Cone
DB2101	28	298A	69976	5570	12.566	Pass		3000	7/24/2024	8/21/2024	Cone & Shear
U922	28	96A	67427	5370	12.566	Pass		3000	7/24/2024	8/21/2024	Cone
U922	28	96A	68612	5460	12.566	Pass		3000	7/24/2024	8/21/2024	Cone
V009	28	232	59167	4710	12.566	Pass	240750	3000	7/24/2024	8/21/2024	Columnar
V009	28	232A	58711	4670	12.566	Pass	240750	3000	7/24/2024	8/21/2024	Columnar
V010	28	109	56079	4460	12.566	Pass	240750	3000	7/24/2024	8/21/2024	Cone & Split
V010	28	109A	58016	4620	12.566	Pass	240750	3000	7/24/2024	8/21/2024	Columnar
V203	28	51A	69513	5530	12.566	Pass	230008	3000	7/24/2024	8/21/2024	Cone & Shear
V203	28	51A	64674	5150	12.566	Pass	230008	3000	7/24/2024	8/21/2024	Cone
V233	28	187A	58682	4670	12.566	Pass		3000	7/24/2024	8/21/2024	Shear
V233	28	187A	60350	4800	12.566	Pass		3000	7/24/2024	8/21/2024	Columnar
V233	28	188A	70665	5620	12.566	Pass		4000	7/24/2024	8/21/2024	Shear

V233	28	188A	67970	5410	12.566	Pass		4000	7/24/2024	8/21/2024	Cone & Shear
V282	28	96	50625	4030	12.566	Pass	240004	3000	7/24/2024	8/21/2024	Cone & Split
V282	28	96A	47377	3770	12.566	Pass	240004	3000	7/24/2024	8/21/2024	Columnar
W181	28	149	79136	6300	12.566	Pass		3000	7/24/2024	8/21/2024	Cone & Shear
W181	28	149A	75858	6040	12.566	Pass		3000	7/24/2024	8/21/2024	Cone & Shear
W181	28	150	98013	7800	12.566	Pass		3000	7/24/2024	8/21/2024	Cone
W181	28	150A	87946	7000	12.566	Pass		3000	7/24/2024	8/21/2024	Cone & Shear
W919	28	23A	56500	4500	12.566	Pass		3000	7/24/2024	8/21/2024	Cone
W919	28	23A	58338	4640	12.566	Pass		3000	7/24/2024	8/21/2024	Columnar
X120	28	16A	63442	5020	12.629	Pass		3000	7/24/2024	8/21/2024	Columnar
X120	28	16A	65546	5220	12.566	Pass		3000	7/24/2024	8/21/2024	Cone
X176	28	8A	55281	4400	12.566	Pass		3000	7/24/2024	8/21/2024	Cone & Split
X176	28	8A	55824	4440	12.566	Pass		3000	7/24/2024	8/21/2024	Columnar
X205	7	27B	68709	5470	12.566	Pass	240210	3000	8/14/2024	8/21/2024	Cone & Split
X205	7	27B	70148	5580	12.566	Pass	240210	3000	8/14/2024	8/21/2024	Cone & Shear
X251	28	97V	139130	11130	12.504	Pass		10000	7/24/2024	8/21/2024	Cone & Shear
X251	28	97V	141658	11270	12.566	Pass		10000	7/24/2024	8/21/2024	Columnar
X308	28	12VRK	180396	14360	12.566	Pass		9000	7/24/2024	8/21/2024	Cone
X308	28	12VRK	182640	14530	12.566	Pass		9000	7/24/2024	8/21/2024	Cone
X319	28	17A	56914	4530	12.566	Pass		3000	7/24/2024	8/21/2024	Cone & Shear
X319	28	17A	57833	4600	12.566	Pass		3000	7/24/2024	8/21/2024	Cone & Shear
X394	7	11B	57323	4560	12.566	Pass	240402	3000	8/14/2024	8/21/2024	Cone & Shear
X394	7	11B	51693	4110	12.566	Pass	240402	3000	8/14/2024	8/21/2024	Cone
X412	28	2A	82177	6570	12.504	Pass		3000	7/24/2024	8/21/2024	Cone & Shear
X412	28	2A	78593	6250	12.566	Pass		3000	7/24/2024	8/21/2024	Shear
Y069	28	3A	68636	5460	12.566	Pass		3000	7/24/2024	8/21/2024	Cone
Y069	28	3A	68236	5430	12.566	Pass		3000	7/24/2024	8/21/2024	Cone
126644	28	13	59668	4750	12.566	Pass	240280	3000	7/25/2024	8/22/2024	Columnar
126644	28	13A	60761	4840	12.566	Pass	240280	3000	7/25/2024	8/22/2024	Cone & Shear
CPI	28	98V	137188	10920	12.566	Pass		8000	7/25/2024	8/22/2024	Cone
CPI	28	98V	139766	11120	12.566	Pass		8000	7/25/2024	8/22/2024	Cone
DB2101	28	299A	50356	4010	12.566	Pass		3000	7/25/2024	8/22/2024	Columnar

DB2101	28	299A	51813	4120	12.566	Pass		3000	7/25/2024	8/22/2024	Cone
SCP	28	1V	153908	12250	12.566	Pass	240247	10000	7/25/2024	8/22/2024	Cone & Shear
SCP	28	1V	146168	11630	12.566	Pass	240247	10000	7/25/2024	8/22/2024	Cone & Shear
SCP	28	2V	150871	12010	12.566	Pass	240247	10000	7/25/2024	8/22/2024	Cone
SCP	28	2V	149050	11860	12.566	Pass	240247	10000	7/25/2024	8/22/2024	Cone
SCP	28	3V	135508	10780	12.566	Pass	240247	10000	7/25/2024	8/22/2024	Cone
SCP	28	3V	125681	10000	12.566	Pass	240247	10000	7/25/2024	8/22/2024	Cone
U922	28	330A	69371	5520	12.566	Pass		3000	7/25/2024	8/22/2024	Cone
U922	28	330A	68571	5460	12.566	Pass		3000	7/25/2024	8/22/2024	Cone
U922	28	326A	85775	6890	12.441	Pass		3000	7/25/2024	8/22/2024	Cone
U922	28	326A	88932	7080	12.566	Pass		3000	7/25/2024	8/22/2024	Cone & Shear
U922	28	327A	81494	6490	12.566	Pass		3000	7/25/2024	8/22/2024	Cone
U922	28	327A	82331	6550	12.566	Pass		3000	7/25/2024	8/22/2024	Columnar
U922	28	328A	72134	5740	12.566	Pass		3000	7/25/2024	8/22/2024	Cone
U922	28	328A	78313	6230	12.566	Pass		3000	7/25/2024	8/22/2024	Cone
U922	28	329A	73114	5820	12.566	Pass		3000	7/25/2024	8/22/2024	Columnar
U922	28	329A	72039	5730	12.566	Pass		3000	7/25/2024	8/22/2024	Cone & Shear
U922	28	331A	60604	4820	12.566	Pass		3000	7/25/2024	8/22/2024	Cone & Shear
U922	28	331A	59709	4750	12.566	Pass		3000	7/25/2024	8/22/2024	Cone
V009	28	233	65140	5180	12.566	Pass	240750	3000	7/25/2024	8/22/2024	Cone & Shear
V009	28	233A	63222	5030	12.566	Pass	240750	3000	7/25/2024	8/22/2024	Cone & Split
V010	28	110	69018	5490	12.566	Pass	240750	3000	7/25/2024	8/22/2024	Cone & Shear
V010	28	110A	70676	5620	12.566	Pass	240750	3000	7/25/2024	8/22/2024	Columnar
V203	28	52	78608	6260	12.566	Pass	240064	3000	7/25/2024	8/22/2024	Columnar
V203	28	52A	73651	5860	12.566	Pass	240064	3000	7/25/2024	8/22/2024	Cone
W055	28	418A	154759	5470	28.274	Pass	240408	3000	7/25/2024	8/22/2024	Columnar
W055	28	418A	141527	5010	28.274	Pass	240408	3000	7/25/2024	8/22/2024	Columnar
W181	28	151	154991	5460	28.369	Pass		3000	7/25/2024	8/22/2024	Cone & Shear
W181	28	151A	155500	5500	28.274	Pass		3000	7/25/2024	8/22/2024	Cone
W181	28	152	89649	7130	12.566	Pass		3000	7/25/2024	8/22/2024	Cone
W181	28	152A	90133	7170	12.566	Pass		3000	7/25/2024	8/22/2024	Cone
W231	28	40A	55775	4440	12.566	Pass		3000	7/25/2024	8/22/2024	Cone & Shear

W231	28	40A	60265	4800	12.566	Pass		3000	7/25/2024	8/22/2024	Cone
W388	28	40A	62246	4950	12.566	Pass		3000	7/25/2024	8/22/2024	Cone & Shear
W388	28	40A	66476	5290	12.566	Pass		3000	7/25/2024	8/22/2024	Cone & Shear
X119	28	89A	81604	6560	12.441	Pass		3000	7/25/2024	8/22/2024	Cone
X119	28	89A	79634	6340	12.566	Pass		3000	7/25/2024	8/22/2024	Cone & Shear
X120	28	17A	52210	4150	12.566	Pass		3000	7/25/2024	8/22/2024	Cone & Shear
X120	28	17A	54830	4360	12.566	Pass		3000	7/25/2024	8/22/2024	Cone & Split
X135	10	25B	40670	3240	12.566	Pass	240238	3000	8/12/2024	8/22/2024	Columnar
X135	10	25B	39830	3170	12.566	Pass	240238	3000	8/12/2024	8/22/2024	Shear
X205	7	28B	69044	5490	12.566	Pass	240210	3000	8/15/2024	8/22/2024	Cone & Shear
X205	7	28B	67439	5370	12.566	Pass	240210	3000	8/15/2024	8/22/2024	Columnar
X267	7	8B	55581	4420	12.566	Pass	240071	3000	8/15/2024	8/22/2024	Cone & Split
X267	7	8C	50612	4030	12.566	Pass	240071	3000	8/15/2024	8/22/2024	Cone & Shear
X306	28	10A	72513	5770	12.566	Pass	240445	3000	7/25/2024	8/22/2024	Cone & Shear
X306	28	10B	68030	5410	12.566	Pass	240445	3000	7/25/2024	8/22/2024	Columnar
X308	28	100A	93270	7420	12.566	Pass		3000	7/25/2024	8/22/2024	Cone & Shear
X308	28	100A	91889	7310	12.566	Pass		3000	7/25/2024	8/22/2024	Cone
Y069	28	4A	71531	5690	12.566	Pass		3000	7/25/2024	8/22/2024	Columnar
Y069	28	4A	68951	5490	12.566	Pass		3000	7/25/2024	8/22/2024	Columnar
Y080	28	21A	50098	4010	12.504	Pass		3000	7/25/2024	8/22/2024	Cone & Shear
Y080	28	21A	51230	4080	12.566	Pass		3000	7/25/2024	8/22/2024	Cone & Split
Y138	28	4A	66499	5290	12.566	Pass		3000	7/25/2024	8/22/2024	Cone & Shear
Y138	28	4A	62030	4940	12.566	Pass		3000	7/25/2024	8/22/2024	Columnar
Y146	28	8V	150130	11950	12.566	Pass		10000	7/25/2024	8/22/2024	Cone & Shear
Y146	28	8V	136980	10900	12.566	Pass		10000	7/25/2024	8/22/2024	Columnar
126644	28	14	63293	5040	12.566	Pass	240280	3000	7/26/2024	8/23/2024	Columnar
126644	28	14A	63112	5020	12.566	Pass	240280	3000	7/26/2024	8/23/2024	Cone
CPI	28	99V	137045	10910	12.566	Pass		8000	7/26/2024	8/23/2024	Columnar
CPI	28	99V	134595	10710	12.566	Pass		8000	7/26/2024	8/23/2024	Cone
DB2101	28	300A	60829	4840	12.566	Pass		3000	7/26/2024	8/23/2024	Cone & Split
DB2101	28	300A	64479	5130	12.566	Pass		3000	7/26/2024	8/23/2024	Cone & Shear
DB2101	28	301A	58244	4630	12.566	Pass		3000	7/26/2024	8/23/2024	Columnar

DB2101	28	301A	53804	4280	12.566	Pass		3000	7/26/2024	8/23/2024	Columnar
V009	28	234	62588	4980	12.566	Pass	240750	3000	7/26/2024	8/23/2024	Cone & Shear
V009	28	234A	62294	4960	12.566	Pass	240750	3000	7/26/2024	8/23/2024	Columnar
V203	28	53	63320	5040	12.566	Pass	240064	3000	7/26/2024	8/23/2024	Cone & Shear
V203	28	53A	63449	5050	12.566	Pass	240064	3000	7/26/2024	8/23/2024	Columnar
V257	28	118A	81824	6510	12.566	Pass		3000	7/26/2024	8/23/2024	Cone & Shear
V257	28	118A	81578	6490	12.566	Pass		3000	7/26/2024	8/23/2024	Cone
V300	28	50VRK	178674	14150	12.629	Pass		10000	7/26/2024	8/23/2024	Cone
V300	28	50VRK	182146	14490	12.566	Pass		10000	7/26/2024	8/23/2024	Cone
W068	28	11A	84992	6760	12.566	Pass		3000	7/26/2024	8/23/2024	Columnar
W068	28	11A	85129	6770	12.566	Pass		3000	7/26/2024	8/23/2024	Columnar
W181	28	153	164411	5810	28.274	Pass		3000	7/26/2024	8/23/2024	Columnar
W181	28	153A	165026	5840	28.274	Pass		3000	7/26/2024	8/23/2024	Cone & Shear
W181	28	154	89023	7080	12.566	Pass		3000	7/26/2024	8/23/2024	Cone & Shear
W181	28	154A	93194	7420	12.566	Pass		3000	7/26/2024	8/23/2024	Columnar
W265	28	30A	63794	5080	12.566	Pass		3000	7/26/2024	8/23/2024	Cone
W265	28	30A	70634	5620	12.566	Pass		3000	7/26/2024	8/23/2024	Cone & Shear
W374	28	34A	61205	4870	12.566	Pass		3000	7/26/2024	8/23/2024	Cone
W374	28	34A	60425	4810	12.566	Pass		3000	7/26/2024	8/23/2024	Cone & Shear
X120	28	18A	78658	6260	12.566	Pass		3000	7/26/2024	8/23/2024	Cone & Shear
X120	28	18A	77791	6190	12.566	Pass		3000	7/26/2024	8/23/2024	Cone
X267	28	1	76571	6090	12.566	Pass	240071	3000	7/26/2024	8/23/2024	Columnar
X267	28	1A	75058	5970	12.566	Pass	240071	3000	7/26/2024	8/23/2024	Cone & Split
X267	28	2	85628	6810	12.566	Pass	240712	3000	7/26/2024	8/23/2024	Cone
X267	28	2A	85060	6770	12.566	Pass	240712	3000	7/26/2024	8/23/2024	Cone
X308	28	101A	105692	8410	12.566	Pass		3000	7/26/2024	8/23/2024	Cone & Shear
X308	28	101A	102174	8130	12.566	Pass		3000	7/26/2024	8/23/2024	Cone
X350	28	12A	61928	4980	12.441	Pass		3000	7/26/2024	8/23/2024	Cone & Shear
X350	28	12A	59837	4760	12.566	Pass		3000	7/26/2024	8/23/2024	Columnar
X358	28	5VRB	120836	< 9620	12.566	Fail		10000	7/26/2024	8/23/2024	Cone
X358	28	5VRB	125145	< 9960	12.566	Fail		10000	7/26/2024	8/23/2024	Cone & Shear
X358	28	27A	91098	7250	12.566	Pass		4000	7/26/2024	8/23/2024	Cone & Shear

X358	28	27A	97668	7770	12.566	Pass	4000	7/26/2024	8/23/2024	Columnar
X362	28	11	113296	4010	28.274	Pass	3000	7/26/2024	8/23/2024	Cone & Shear
X362	28	11A	106833	3780	28.274	Pass	3000	7/26/2024	8/23/2024	Cone & Shear
Y061	28	7A	116815	9300	12.566	Pass	4000	7/26/2024	8/23/2024	Cone & Split
Y061	28	7A	110155	8770	12.566	Pass	4000	7/26/2024	8/23/2024	Cone
Y111	28	1A	93224	7460	12.504	Pass	3000	7/26/2024	8/23/2024	Cone & Shear
Y111	28	1A	94071	7490	12.566	Pass	3000	7/26/2024	8/23/2024	Shear
Y111	28	1Z	85828	6830	12.566	Pass	3000	7/26/2024	8/23/2024	Cone & Shear
Y111	28	1Z	90033	7160	12.566	Pass	3000	7/26/2024	8/23/2024	Cone
Y146	28	9V	149364	11890	12.566	Pass	10000	7/26/2024	8/23/2024	Cone
Y146	28	9V	157906	12570	12.566	Pass	10000	7/26/2024	8/23/2024	Cone
Y146	28	10V	145039	11540	12.566	Pass	10000	7/26/2024	8/23/2024	Cone
Y146	28	10V	142667	11350	12.566	Pass	10000	7/26/2024	8/23/2024	Cone & Shear
Y178	28	3A	47321	3770	12.566	Pass	3000	7/26/2024	8/23/2024	Cone & Split
Y178	28	3A	53777	4280	12.566	Pass	3000	7/26/2024	8/23/2024	Cone & Shear

(lbf)

(psi)

(in²)

(psi)