

Contract	Age	Cylinder	LBF	PSI	Area	P/F	Design	Required	Made	Tested	Fracture
DB2101	30	302A	63548	5060	12.566	Pass		3000	7/27/2024	8/26/2024	Columnar
DB2101	30	302A	63512	5050	12.566	Pass		3000	7/27/2024	8/26/2024	Cone
DB2101	28	303A	57461	4570	12.566	Pass		3000	7/29/2024	8/26/2024	Columnar
DB2101	28	303A	55377	4410	12.566	Pass		3000	7/29/2024	8/26/2024	Cone & Shear
V009	28	235	50224	4000	12.566	Pass	240750	3000	7/29/2024	8/26/2024	Columnar
V009	28	235A	52414	4170	12.566	Pass	240750	3000	7/29/2024	8/26/2024	Cone & Shear
V203	28	54	58213	4630	12.566	Pass	240064	3000	7/29/2024	8/26/2024	Shear
V203	28	54A	60052	4780	12.566	Pass	240064	3000	7/29/2024	8/26/2024	Cone
V300	28	108	65002	5170	12.566	Pass	240912	4000	7/29/2024	8/26/2024	Cone
V300	28	108A	67379	5360	12.566	Pass	240912	4000	7/29/2024	8/26/2024	Cone & Shear
W055	28	419A	76737	6110	12.566	Pass	240404	3000	7/29/2024	8/26/2024	Cone
W055	28	419A	74208	5910	12.566	Pass	240404	3000	7/29/2024	8/26/2024	Cone
W055	28	420A	83912	6680	12.566	Pass	240372	3000	7/29/2024	8/26/2024	Cone
W055	28	420A	84439	6720	12.566	Pass	240372	3000	7/29/2024	8/26/2024	Cone & Shear
W075	28	30A	26285	< 2090	12.566	Fail		3000	7/29/2024	8/26/2024	Columnar
W075	28	30A	27640	< 2200	12.566	Fail		3000	7/29/2024	8/26/2024	Cone & Shear
W181	9	170B	55967	4450	12.566	Pass	240321	4000	8/17/2024	8/26/2024	Cone
W181	9	170C	58782	4680	12.566	Pass	240321	4000	8/17/2024	8/26/2024	Cone
W181	28	155	170695	6040	28.274	Pass		3000	7/29/2024	8/26/2024	Cone & Shear
W181	28	155A	166355	5880	28.274	Pass		3000	7/29/2024	8/26/2024	Cone & Shear
W181	28	155AR	160185	5670	28.274	Pass	240822	3000	7/29/2024	8/26/2024	Cone & Shear
W181	28	155AR1	174409	6170	28.274	Pass	240822	3000	7/29/2024	8/26/2024	Cone & Shear
W181	5	171B	41254	< 3280	12.566	Fail	240321	4000	8/21/2024	8/26/2024	Columnar
W181	5	171C	44622	< 3550	12.566	Fail	240321	4000	8/21/2024	8/26/2024	Cone & Shear
W181	5	172B	41414	< 3300	12.566	Fail	240321	4000	8/21/2024	8/26/2024	Cone & Shear
W181	5	172C	40812	< 3250	12.566	Fail	240321	4000	8/21/2024	8/26/2024	Cone
W181	5	173B	52100	4150	12.566	Pass	240321	4000	8/21/2024	8/26/2024	Cone & Shear
W181	5	173C	50634	4030	12.566	Pass	240321	4000	8/21/2024	8/26/2024	Cone & Shear
W374	28	35A	72689	5780	12.566	Pass		3000	7/29/2024	8/26/2024	Columnar
W374	28	35A	68677	5470	12.566	Pass		3000	7/29/2024	8/26/2024	Cone & Shear
X135	28	22A	53708	4270	12.566	Pass	240433	3000	7/29/2024	8/26/2024	Cone & Shear

X135	28	22A	50537	4020	12.566	Pass	240433	3000	7/29/2024	8/26/2024	Cone & Shear
X267	7	9B	66584	5300	12.566	Pass	240071	3000	8/19/2024	8/26/2024	Cone & Shear
X267	7	9C	68393	5440	12.566	Pass	240071	3000	8/19/2024	8/26/2024	Shear
X308	28	13VRK	184418	14680	12.566	Pass		9000	7/29/2024	8/26/2024	Cone
X308	28	13VRK	183143	14570	12.566	Pass		9000	7/29/2024	8/26/2024	Cone
X309	28	11A	63570	5060	12.566	Pass		3000	7/29/2024	8/26/2024	Columnar
X309	28	11A	61515	4900	12.566	Pass		3000	7/29/2024	8/26/2024	Columnar
X309	28	12A	61974	4930	12.566	Pass		3000	7/29/2024	8/26/2024	Columnar
X309	28	12A	60291	4800	12.566	Pass		3000	7/29/2024	8/26/2024	Cone & Shear
Y061	30	8A	116478	9220	12.629	Pass		3000	7/27/2024	8/26/2024	Cone
Y061	30	8A	117792	9370	12.566	Pass		3000	7/27/2024	8/26/2024	Cone
Y061	30	9A	127901	10180	12.566	Pass		4000	7/27/2024	8/26/2024	Cone
Y061	30	9A	130285	10370	12.566	Pass		4000	7/27/2024	8/26/2024	Cone
Y061	30	10A	114033	9070	12.566	Pass		4000	7/27/2024	8/26/2024	Cone & Split
Y061	30	10A	117247	9330	12.566	Pass		4000	7/27/2024	8/26/2024	Cone
Y061	30	11A	110118	8760	12.566	Pass		4000	7/27/2024	8/26/2024	Cone
Y061	30	11A	112085	8920	12.566	Pass		4000	7/27/2024	8/26/2024	Cone
Y064	30	9A	99570	7920	12.566	Pass	240659	3000	7/27/2024	8/26/2024	Cone
Y064	30	9A	93264	7420	12.566	Pass	240659	3000	7/27/2024	8/26/2024	Cone
Y080	28	22A	52148	4150	12.566	Pass		3000	7/29/2024	8/26/2024	Cone & Shear
Y080	28	22A	51819	4120	12.566	Pass		3000	7/29/2024	8/26/2024	Cone & Shear
Y138	28	5A	55780	4460	12.504	Pass		3000	7/29/2024	8/26/2024	Cone & Shear
Y138	28	5A	52621	4190	12.566	Pass		3000	7/29/2024	8/26/2024	Cone & Split
Y146	28	45V	138425	11070	12.504	Pass		10000	7/29/2024	8/26/2024	Cone
Y146	28	45V	143302	11400	12.566	Pass		10000	7/29/2024	8/26/2024	Columnar
Y146	28	46V	136323	10850	12.566	Pass		10000	7/29/2024	8/26/2024	Cone
Y146	28	46V	135753	10800	12.566	Pass		10000	7/29/2024	8/26/2024	Columnar
Y146	28	47V	149482	11900	12.566	Pass		10000	7/29/2024	8/26/2024	Cone
Y146	28	47V	138582	11030	12.566	Pass		10000	7/29/2024	8/26/2024	Cone & Shear
Y147	28	1	53846	4280	12.566	Pass	240238	3000	7/29/2024	8/26/2024	Cone & Shear
Y147	28	1A	48704	3880	12.566	Pass	240238	3000	7/29/2024	8/26/2024	Columnar
CPI	28	100V	142448	11340	12.566	Pass		10000	7/30/2024	8/27/2024	Cone

CPI	28	100V	142450	11340	12.566	Pass		10000	7/30/2024	8/27/2024	Cone
DB2101	28	304A	50903	4050	12.566	Pass		3000	7/30/2024	8/27/2024	<None>
DB2101	28	304A	50986	4060	12.566	Pass		3000	7/30/2024	8/27/2024	Cone & Shear
DB2301	28	1	46037	3650	12.629	Pass		3000	7/30/2024	8/27/2024	Columnar
DB2301	28	1A	47416	3770	12.566	Pass		3000	7/30/2024	8/27/2024	Cone
T023	28	492A	70789	5660	12.504	Pass		3000	7/30/2024	8/27/2024	Shear
T023	28	492A	64309	5120	12.566	Pass		3000	7/30/2024	8/27/2024	Columnar
U922	28	97A	43890	3490	12.566	Pass		3000	7/30/2024	8/27/2024	Columnar
U922	28	97A	47092	3750	12.566	Pass		3000	7/30/2024	8/27/2024	Columnar
V130	28	222A	51536	4100	12.566	Pass	240169	3000	7/30/2024	8/27/2024	Cone
V130	28	222A	54087	4300	12.566	Pass	240169	3000	7/30/2024	8/27/2024	Cone
V203	28	55	60595	4820	12.566	Pass	240064	3000	7/30/2024	8/27/2024	Cone & Shear
V203	28	55A	64815	5160	12.566	Pass	240064	3000	7/30/2024	8/27/2024	Cone & Shear
W055	28	421	94200	7500	12.566	Pass	240404	3000	7/30/2024	8/27/2024	Cone
W055	28	421A	96343	7670	12.566	Pass	240404	3000	7/30/2024	8/27/2024	Cone
W055	28	422A	78230	6230	12.566	Pass	240342	3000	7/30/2024	8/27/2024	Columnar
W055	28	422A	80121	6380	12.566	Pass	240342	3000	7/30/2024	8/27/2024	Cone & Shear
W181	28	156	160567	5660	28.369	Pass		3000	7/30/2024	8/27/2024	Cone & Shear
W181	28	156A	164582	5820	28.274	Pass		3000	7/30/2024	8/27/2024	Cone & Shear
X229	28	34A	63115	5020	12.566	Pass		3000	7/30/2024	8/27/2024	Cone & Shear
X229	28	34A	59487	4730	12.566	Pass		3000	7/30/2024	8/27/2024	Columnar
X267	5	11B	41998	< 3340	12.566	Fail	240714	4000	8/22/2024	8/27/2024	Cone
X267	5	11C	41960	< 3340	12.566	Fail	240714	4000	8/22/2024	8/27/2024	Cone & Shear
X308	28	102A	79134	6300	12.566	Pass		3000	7/30/2024	8/27/2024	Cone & Shear
X308	28	102A	79103	6290	12.566	Pass		3000	7/30/2024	8/27/2024	Cone & Shear
X309	28	13A	65475	5210	12.566	Pass		3000	7/30/2024	8/27/2024	Columnar
X309	28	13A	67212	5350	12.566	Pass		3000	7/30/2024	8/27/2024	Cone & Shear
X309	28	14A	77914	6200	12.566	Pass		3000	7/30/2024	8/27/2024	Cone & Shear
X309	28	14A	75422	6000	12.566	Pass		3000	7/30/2024	8/27/2024	Shear
Y026	28	1	52967	4210	12.566	Pass		3000	7/30/2024	8/27/2024	Columnar
Y026	28	1A	54963	4370	12.566	Pass		3000	7/30/2024	8/27/2024	Cone & Shear
Y061	28	12A	113695	9050	12.566	Pass		4000	7/30/2024	8/27/2024	Cone

Y061	28	12A	112302	8940	12.566	Pass		4000	7/30/2024	8/27/2024	Cone
Y178	28	4A	58630	4670	12.566	Pass		3000	7/31/2024	8/28/2024	Cone & Shear
Y178	28	4A	57286	4560	12.566	Pass		3000	7/31/2024	8/28/2024	Columnar
CPI	28	101V	149154	11870	12.566	Pass		10000	7/31/2024	8/28/2024	Cone & Shear
CPI	28	101V	144894	11530	12.566	Pass		10000	7/31/2024	8/28/2024	Cone
DB2101	28	305A	62228	4950	12.566	Pass		3000	7/31/2024	8/28/2024	Columnar
DB2101	28	305A	62885	5000	12.566	Pass		3000	7/31/2024	8/28/2024	Cone & Shear
SCP	28	4V	160900	12870	12.504	Pass	240247	10000	7/31/2024	8/28/2024	Cone
SCP	28	4V	159130	12660	12.566	Pass	240247	10000	7/31/2024	8/28/2024	Cone
SCP	28	5V	138248	11000	12.566	Pass	240247	10000	7/31/2024	8/28/2024	Cone
SCP	28	5V	133647	10640	12.566	Pass	240247	10000	7/31/2024	8/28/2024	Cone
SCP	28	6V	136102	10830	12.566	Pass	240247	10000	7/31/2024	8/28/2024	Cone & Split
SCP	28	6V	138597	11030	12.566	Pass	240247	10000	7/31/2024	8/28/2024	Cone
V130	28	223A	60865	4840	12.566	Pass	240169	3000	7/31/2024	8/28/2024	Cone & Shear
V130	28	223A	60808	4840	12.566	Pass	240169	3000	7/31/2024	8/28/2024	Columnar
V203	28	56	57163	4550	12.566	Pass	240064	3000	7/31/2024	8/28/2024	Cone
V203	28	56A	58768	4680	12.566	Pass	240064	3000	7/31/2024	8/28/2024	Columnar
V282	28	97	47134	3750	12.566	Pass	240004	3000	7/31/2024	8/28/2024	Columnar
V282	28	97A	48467	3860	12.566	Pass	240004	3000	7/31/2024	8/28/2024	Columnar
W055	28	423A	71608	5700	12.566	Pass	240342	3000	7/31/2024	8/28/2024	Cone & Shear
W055	28	423A	72893	5800	12.566	Pass	240342	3000	7/31/2024	8/28/2024	Cone & Split
W068	28	12A	99367	7910	12.566	Pass		3000	7/31/2024	8/28/2024	Columnar
W068	28	12A	100035	7960	12.566	Pass		3000	7/31/2024	8/28/2024	Columnar
W110	28	115	82880	6600	12.566	Pass	240426	3000	7/31/2024	8/28/2024	Cone
W110	28	115A	79678	6340	12.566	Pass	240426	3000	7/31/2024	8/28/2024	Cone
W181	28	157	146301	5170	28.274	Pass		3000	7/31/2024	8/28/2024	Columnar
W181	28	157A	147463	5220	28.274	Pass		3000	7/31/2024	8/28/2024	Cone & Shear
W181	28	158	62233	4950	12.566	Pass		3000	7/31/2024	8/28/2024	Columnar
W181	28	158A	62620	4980	12.566	Pass		3000	7/31/2024	8/28/2024	Columnar
W181	28	158AR	56938	4530	12.566	Pass	240712	3000	7/31/2024	8/28/2024	Columnar
W181	28	158AR1	59177	4710	12.566	Pass	240712	3000	7/31/2024	8/28/2024	Cone
W181	7	171D	41794	< 3330	12.566	Fail	240321	4000	8/21/2024	8/28/2024	Columnar

W181	7	171E	42349	< 3370	12.566	Fail	240321	4000	8/21/2024	8/28/2024	Columnar
W181	7	172D	38939	< 3100	12.566	Fail	240321	4000	8/21/2024	8/28/2024	Columnar
W181	7	172E	39162	< 3120	12.566	Fail	240321	4000	8/21/2024	8/28/2024	Cone & Shear
W181	7	174B	47844	3810	12.566	Pass	240012	3000	8/21/2024	8/28/2024	Columnar
W181	7	174C	49711	3960	12.566	Pass	240012	3000	8/21/2024	8/28/2024	Columnar
W265	28	31A	73290	5830	12.566	Pass		4000	7/31/2024	8/28/2024	Cone & Shear
W265	28	31A	77744	6190	12.566	Pass		4000	7/31/2024	8/28/2024	Cone & Shear
X119	28	90A	53496	4260	12.566	Pass		3000	7/31/2024	8/28/2024	Columnar
X119	28	90A	56258	4480	12.566	Pass		3000	7/31/2024	8/28/2024	Cone & Shear
X205	7	29B	56988	4530	12.566	Pass	240210	3000	8/21/2024	8/28/2024	Cone & Shear
X205	7	29B	59539	4740	12.566	Pass	240210	3000	8/21/2024	8/28/2024	Cone & Shear
X267	7	10B	78154	6220	12.566	Pass	240071	3000	8/21/2024	8/28/2024	Columnar
X267	7	10C	71140	5660	12.566	Pass	240071	3000	8/21/2024	8/28/2024	Cone & Shear
X306	28	11A	61169	4840	12.629	Pass		3000	7/31/2024	8/28/2024	Columnar
X306	28	11B	62078	4940	12.566	Pass		3000	7/31/2024	8/28/2024	Cone & Shear
X309	28	15A	64554	5140	12.566	Pass		3000	7/31/2024	8/28/2024	Columnar
X309	28	15A	65749	5230	12.566	Pass		3000	7/31/2024	8/28/2024	Cone & Shear
X319	28	18A	47393	3770	12.566	Pass		3000	7/31/2024	8/28/2024	Cone & Split
X319	28	18A	44608	3550	12.566	Pass		3000	7/31/2024	8/28/2024	Cone & Shear
X358	28	28A	85708	6820	12.566	Pass		4000	7/31/2024	8/28/2024	Cone & Split
X358	28	28A	89236	7100	12.566	Pass		4000	7/31/2024	8/28/2024	Cone
X370	28	1A	118817	9460	12.566	Pass		3000	7/31/2024	8/28/2024	Cone
X370	28	1A	117224	9330	12.566	Pass		3000	7/31/2024	8/28/2024	Cone & Shear
X394	28	6A	92516	7360	12.566	Pass		3000	7/31/2024	8/28/2024	Cone & Shear
X394	28	6A	94091	7490	12.566	Pass		4000	7/31/2024	8/28/2024	Cone
X394	28	7A	94063	7520	12.504	Pass		4000	7/31/2024	8/28/2024	Cone
X394	28	7A	103520	8240	12.566	Pass		4000	7/31/2024	8/28/2024	Cone
Y034	28	4A	66776	5310	12.566	Pass		3000	7/31/2024	8/28/2024	Columnar
Y034	28	4A	71273	5670	12.566	Pass		3000	7/31/2024	8/28/2024	Cone & Shear
Y080	28	23A	53013	4220	12.566	Pass		3000	7/31/2024	8/28/2024	Columnar
Y080	28	23A	54712	4350	12.566	Pass		3000	7/31/2024	8/28/2024	Cone & Shear
Y138	28	6A	59456	4780	12.441	Pass		3000	7/31/2024	8/28/2024	Cone & Shear

Y138	28	6A	58161	4630	12.566	Pass		3000	7/31/2024	8/28/2024	Columnar
Y146	28	11V	140340	11170	12.566	Pass		10000	7/31/2024	8/28/2024	Cone & Shear
Y146	28	11V	144147	11470	12.566	Pass		10000	7/31/2024	8/28/2024	Cone & Shear
Y146	28	12V	144290	11480	12.566	Pass		10000	7/31/2024	8/28/2024	Cone
Y146	28	12V	126835	10090	12.566	Pass		10000	7/31/2024	8/28/2024	Cone
CPI	28	49V	124328	9890	12.566	Pass		8000	8/1/2024	8/29/2024	Columnar
CPI	28	49V	127327	10130	12.566	Pass		8000	8/1/2024	8/29/2024	Cone & Split
CPI	28	50V	128765	10250	12.566	Pass		8000	8/1/2024	8/29/2024	Cone & Shear
CPI	28	50V	125805	10010	12.566	Pass		8000	8/1/2024	8/29/2024	Cone & Shear
DB2101	28	306A	58742	4670	12.566	Pass		3000	8/1/2024	8/29/2024	Columnar
DB2101	28	306A	57079	4540	12.566	Pass		3000	8/1/2024	8/29/2024	Cone & Shear
T023	28	493A	54498	4340	12.566	Pass		3000	8/1/2024	8/29/2024	Cone & Shear
T023	28	493A	55419	4410	12.566	Pass		3000	8/1/2024	8/29/2024	Columnar
T023	28	494A	50989	4060	12.566	Pass		3000	8/1/2024	8/29/2024	Columnar
T023	28	494A	49691	3950	12.566	Pass		3000	8/1/2024	8/29/2024	Cone
V009	28	236	54287	4320	12.566	Pass	240750	3000	8/1/2024	8/29/2024	Cone
V009	28	236A	56953	4530	12.566	Pass	240750	3000	8/1/2024	8/29/2024	Columnar
V233	28	189A	59480	4780	12.441	Pass		3000	8/1/2024	8/29/2024	Cone & Shear
V233	28	189A	59670	4750	12.566	Pass		3000	8/1/2024	8/29/2024	Columnar
V282	28	98	43051	3430	12.566	Pass	240004	3000	8/1/2024	8/29/2024	Columnar
V282	28	98A	42966	3420	12.566	Pass	240004	3000	8/1/2024	8/29/2024	Columnar
W055	28	424A	74807	5950	12.566	Pass	240409	4000	8/1/2024	8/29/2024	Cone & Shear
W055	28	424A	75625	6020	12.566	Pass	240409	4000	8/1/2024	8/29/2024	Columnar
W055	28	424B	84771	6750	12.566	Pass	240409	4000	8/1/2024	8/29/2024	Cone
W055	28	424B	80033	6370	12.566	Pass	240409	4000	8/1/2024	8/29/2024	Cone
W181	28	159	75419	6000	12.566	Pass		3000	8/1/2024	8/29/2024	Cone & Shear
W181	28	159A	74410	5920	12.566	Pass		3000	8/1/2024	8/29/2024	Cone & Shear
W265	28	32A	66734	5310	12.566	Pass		4000	8/1/2024	8/29/2024	Cone
W265	28	32A	64336	5120	12.566	Pass		4000	8/1/2024	8/29/2024	Cone & Shear
X053	28	32A	109846	8740	12.566	Pass		3000	8/1/2024	8/29/2024	Cone
X053	28	32A	116487	9270	12.566	Pass		3000	8/1/2024	8/29/2024	Cone & Shear
X135	28	23A	55042	4380	12.566	Pass	240238	3000	8/1/2024	8/29/2024	Columnar

X135	28	23A	58930	4690	12.566	Pass	240238	3000	8/1/2024	8/29/2024	Cone
X143	28	23A	53370	4250	12.566	Pass		3000	8/1/2024	8/29/2024	Cone
X143	28	23A	57434	4570	12.566	Pass		3000	8/1/2024	8/29/2024	Cone & Shear
X250	28	1A	54663	4350	12.566	Pass		3000	8/1/2024	8/29/2024	Cone
X250	28	1A	57085	4540	12.566	Pass		3000	8/1/2024	8/29/2024	Columnar
X267	28	3	58515	4660	12.566	Pass	240071	3000	8/1/2024	8/29/2024	Columnar
X267	28	3A	62500	4970	12.566	Pass	240071	3000	8/1/2024	8/29/2024	Columnar
X267	7	11D	48093	< 3830	12.566	Fail	240714	4000	8/22/2024	8/29/2024	Columnar
X267	7	11E	48944	< 3890	12.566	Fail	240714	4000	8/22/2024	8/29/2024	Cone & Shear
X267	7	12B	57397	4570	12.566	Pass	240071	3000	8/22/2024	8/29/2024	Cone & Shear
X267	7	12C	58144	4630	12.566	Pass	240071	3000	8/22/2024	8/29/2024	Shear
X358	28	6VRB	133215	10650	12.504	Pass		10000	8/1/2024	8/29/2024	Cone
X358	28	6VRB	140495	11180	12.566	Pass		10000	8/1/2024	8/29/2024	Cone
X358	28	29A	78200	6220	12.566	Pass		3000	8/1/2024	8/29/2024	Cone & Split
X358	28	29A	75682	6020	12.566	Pass		3000	8/1/2024	8/29/2024	Cone & Split
X400	28	10	56078	4460	12.566	Pass	240765	3000	8/1/2024	8/29/2024	Columnar
X400	28	10A	53094	4230	12.566	Pass	240765	3000	8/1/2024	8/29/2024	Cone & Shear
Y147	28	2	59306	4720	12.566	Pass	240238	3000	8/1/2024	8/29/2024	Columnar
Y147	28	2A	59113	4700	12.566	Pass	240238	3000	8/1/2024	8/29/2024	Columnar
X412	28	3A	72497	5740	12.629	Pass		4000	8/1/2024	8/29/2024	Cone
X412	28	3A	75269	5990	12.566	Pass		4000	8/1/2024	8/29/2024	Cone
Y069	28	5A	67359	5360	12.566	Pass		3000	8/1/2024	8/29/2024	Cone
Y069	28	5A	73140	5820	12.566	Pass		3000	8/1/2024	8/29/2024	Cone & Shear
Y138	28	7A	55073	4380	12.566	Pass		3000	8/1/2024	8/29/2024	Shear
Y138	28	7A	55002	4380	12.566	Pass		3000	8/1/2024	8/29/2024	Cone
Y146	28	13V	131304	10450	12.566	Pass		10000	8/1/2024	8/29/2024	Cone & Shear
Y146	28	13V	132360	10530	12.566	Pass		10000	8/1/2024	8/29/2024	Cone & Shear
DB2101	28	307A	55694	4430	12.566	Pass		3000	8/2/2024	8/30/2024	Columnar
DB2101	28	307A	58413	4650	12.566	Pass		3000	8/2/2024	8/30/2024	Cone
V281	28	831A	39492	3140	12.566	Pass		3000	8/2/2024	8/30/2024	Columnar
V281	28	831A	35525	< 2830	12.566	Fail		3000	8/2/2024	8/30/2024	Cone & Shear
V282	28	99	44457	3540	12.566	Pass	240004	3000	8/2/2024	8/30/2024	Cone & Shear

V282	28	99A	44840	3570	12.566	Pass	240004	3000	8/2/2024	8/30/2024	Cone
X074	28	5VRK	180746	14310	12.629	Pass		10000	8/2/2024	8/30/2024	Cone
X074	28	5VRK	181705	14460	12.566	Pass		10000	8/2/2024	8/30/2024	Cone
X205	7	30B	65933	5250	12.566	Pass	240210	3000	8/23/2024	8/30/2024	Columnar
X205	7	30B	64723	5150	12.566	Pass	240210	3000	8/23/2024	8/30/2024	Columnar
X250	28	2A	49919	3970	12.566	Pass		3000	8/2/2024	8/30/2024	Columnar
X250	28	2A	49470	3940	12.566	Pass		3000	8/2/2024	8/30/2024	Columnar
X306	3	22C	53091	4220	12.566	Pass	240968	4000	8/27/2024	8/30/2024	Cone & Shear
X306	3	22D	51716	4120	12.566	Pass	240968	4000	8/27/2024	8/30/2024	Cone & Shear
X319	28	19A	59737	4780	12.504	Pass		3000	8/2/2024	8/30/2024	Cone
X319	28	19A	58658	4670	12.566	Pass		3000	8/2/2024	8/30/2024	Cone & Shear
Y034	28	5A	55132	4390	12.566	Pass		3000	8/2/2024	8/30/2024	Columnar
Y034	28	5A	55286	4400	12.566	Pass		3000	8/2/2024	8/30/2024	Columnar