

Bridge Deck Construction Post Pour Checklist

PIN: 129888.00

County: Wilson

Federal Project No.: STBG-M-1234(00)

State Project No.: 95LPLM-F3-011

1. Check curing process every day to be sure deck is kept wet.
Note: Suggest checking early A.M., midday, and late P.M., at a minimum.
2. Check bridge deck for deficiencies using 12' straightedge and/or profilograph as required by specifications and have contractor make necessary corrections.
3. Review "Pre-Pour" and "During Pour" checklists and observations; give written instructions to Contractor concerning any unsatisfactory conditions of deficiencies to insure these are not repeated on next pour.
4. Place copy of all checklists, Pre-Pour Conference minutes, and instructions to Contractor in project file.

Inspector: Jeremy Banks

Title: Bridge Engineer, PCI Consultants

Date: 2/21/19