

TOSHA
MOST CITED for Construction NAICS codes 23
January 2020 – December 2020



TOSHA

TOTAL Number of Violations for calendar year 730

Rank	Standard	Section Title	Violations	Description
1	1926.503(a)(1)	Fall Protection Training	42	Lack of training for employees exposed to fall hazards
2	TDLWD Rule 0800-01-04-.23(4)(a)	Abatement Certification	40	Within ten (10) calendar days after the abatement date, the employer must certify to TOSHA that each cited violation has been abated.
3	1926.453(b)(2)(v)	Aerial Lifts	31	A body belt shall be worn and a lanyard attached to the boom or basket when working from an aerial lift.
4	1926.501(b)(13)	Fall Protection Residential construction	29	"Residential construction." Lack of guardrails, systems, safety net, or fall arrest system during residential construction when exposed to all falls 6 feet or more
5	1926.501(b)(1)	Fall Protection	26	Lack of fall protection when exposed to all falls 6 feet or more
6	1926.1053(b)(1)	Ladders	25	Portable ladder side rails not extending at least 3 feet above the upper landing surface
7	1926.50(c)	Medical Services and First Aid	25	In the absence of a reasonably accessible clinic or hospital, someone on site shall be certified in First Aid
8	1926.102(a)(1)	Eye & Face Protection	23	Lack of eye & face protection when employees are exposed to eye & face hazards
9	1910.1200(c)(1)	Hazard Communication Written Program	20	Lack of a written hazard communication program on site
10	1926.100(a)	Head Protection	19	Lack of head protection when employees are exposed to head injuries

Rank	Standard	Section Title	Violations	Description
11	1910.1200(h)(1)	Hazard Communication Information and Training	19	Lack of employee training for the chemicals in use on the job site
12	1910.1200(g)(8)	Hazard Communication Safety Data Sheets	19	Safety Data Sheets were not available onsite for chemicals used in the workplace
13	1926.652(a)(1)	Excavation Protective Systems	15	Lack of adequate protective system when employees are exposed to a cave-in
14	1926.21(b)(2)	Safety Training & Education	14	Lack of safety training to recognize & avoid unsafe condictions
15	1926.651(k)(1)	Excavations	14	Lack of daily inspection of excavations by competent person
16	1926.1060(a)	Stairways and Ladders Training	13	Training program was not provided to employees
17	1926.1053(b)(13)	Ladder Use	12	The top step of a stepladder shall not be used as a step
18	TDLWD Rule 0800-01-03-.05(1)(a)2	Required Injury/Illness Reporting	11	Failing to report a hospitalization, amputation, or loss of an eye with 24 hours
19	1926.501(b)(11)	Fall Protection Steep-pitch roofs	10	"Steep roofs." Lack of fall protection during roofing when exposed to all falls 6 feet or more on steep pitched roofs
20	1926.454(a)	Scaffolds - Training Requirements	10	Lack of training for employees using scaffolding